

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 5/22/23

Contractor Personnel on Site:

1. Patrick Brown 3. \_\_\_\_\_  
2. \_\_\_\_\_ 4. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. WO#'S , 21801 , 21824 , 21825 , 21874 , 21907 , 21908 ,  
2. 21909 , 21910 , 22070 , 22084 , 22095 , 21875  
3. ASSET#'S , 10043 , 10066 , 10069 , IL-36 , 10044 , 10045 ,  
4. 10067 , 10068 , 10037 , IL-37 , 190917-, 294 , 299 , 280 ,  
5. 281 , 282 , 283 , 284 , 295 , 296 ,

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 5/22/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sgt Tanner, Shane Date: 5/22/23

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**AIR COOLED CHILLER, PACKAGE UNIT**

SITE AND BLDG #: **NY051 BLDG1**MECHANIC  
SIGNATURE:DATE: **5/22/23**LOCATION/RM #: **BLDG1** WO# **22070** ASSET # **10037**START TIME: **9:45am**FINISH TIME: **11am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
2	No intentional venting of refrigerants is permitted. During the servicing, maintenance, and repair of refrigeration equipment, the refrigerant must be recovered.	✓		
3	Whenever refrigerant is added or removed from equipment, record the quantities on the appropriate forms. Forms to be maintained by technician in universal waste binder.		✓	
4	Recover, recycle, or reclaim the refrigerant as appropriate.	✓		
5	If disposal of the equipment item is required, follow regulations concerning removal of refrigerants and disposal of the item.	✓		
6	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.	✓		
7	Refrigerant oils to be treated as hazardous waste.	✓		
8	Closely follow all safety procedures described in the Safety Data Sheet (SDS) for the refrigerant and all labels on refrigerant containers.	✓		
9	Remove access covers prior to accomplishing check points.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
<b>CONDENSER</b>				
1	Remove debris from air screen and clean underneath unit.	✓		
2	Pressure wash coil with proper cleaning solution.		✓	
3	Straighten fin tubes with fin comb.		✓	
4	Check electrical wiring and tighten loose connections. Check fused disconnect switches for condition and operation, contactors	✓		
5	Check mounting for tightness.	✓		
6	Check for corrosion. Clean and treat with inhibitor as needed.	✓		
7	Check fan or blower for bent or damaged blades and imbalance.	✓		

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
8	Lubricate shaft and motor bearings on fans and remove old or excess lubricant, if applicable.	✓		
9	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multi-belt drives should be replaced with matched sets.		✓	
<b>EVAPORATOR</b>				
1	Inspect evaporator for any obvious deficiencies.	✓		
2	Inspect plumbing, valves and flanges for leaks and correct as needed.	✓		
<b>COMPRESSOR(S)</b>				
1	Lubricate drive coupling, if applicable.	✓		
2	Lubricate motor bearings (non-hermetic), if applicable.	✓		
3	Check bearings for vibrations or unusual noises.	✓		
4	Leak test unit with soap test or electronic device.	✓		
5	Check compressor oil level., if applicable.	✓		
6	Run machine; check action of controls, relays, switches, etc. to see that: a. Compressor(s) run at proper settings. b. Suction and discharge pressures are proper.	✓		
7	Check vibration eliminators. Replace as necessary.	✓		
8	Document AMP draw on compressors	✓	✓	L1 /20 L2 /20 L3 /20
9	Check safety controls for high pressure cut off.	✓		
<b>CONTROLS</b>				
1	Record chilled water supply and return temps and Humidity .	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**