

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

AIR CURTAIN

MECHANIC SIGNATURE:

DATE: 17-NOV-2025

SITE AND BLDG #: WV005

LOCATION/RM #: WO# 20506 **ASSET #** 9095

START TIME: 11AM

FINISH TIME: 12PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS
		YES	NO	
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
TO BE PERFORMED AT EACH INSPECT				
1	Disconnect the power to the unit.	●		
2	Remove the intake grille by removing all screws around the edges.	●		
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.	●		
4	If necessary, lubricate the motors.	●		
5	Reinstall the cover and intake grille.	●		
6	Verify proper operation of unit. Make and/or recommend any needed repairs.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Fly curtain is operating flawlessly.
-AS

