




40-115AN-A05 6.0.4
PCBCP137
1503190105



J101

J201

IN1 COM IN2 C R GL W2
AUXILIARY REMOTE TH

Model PTH093G35AXXXCA

Serial 1505057052

	BTU — HR	Watts	Amps	V
Cooling	<u>9000/9000</u>	<u>750/750</u>	<u>4.1/4.1</u>	<u>19</u>
Rev. Cyc. Heat	<u>8300/8100</u>	<u>715/695</u>	<u>4.1/4.1</u>	
Resistance Heat	<u>12000/9900</u>	<u>3550/2910</u>	<u>15.4/14.0</u>	Hz

Compressor	RLA	<u>3.5</u>		LRA	<u>16.5</u>	
Indoor Fan	FLA	<u>0.22</u>	HP	<u>0.02</u>	LRA	<u>0.25</u>
Outdoor Fan	FLA	<u>0.34</u>	HP	<u>0.05</u>	LRA	<u>0.45</u>
Resistance Heater	KW	<u>3.5</u>				

Design Pressure PSIG High Side 450
Design Pressure PSIG Low Side 236

Refrigerant R — 410A (ozs) 34.6
Min Circuit Ampacity 19.3
Max Overcurrent Devlooe 20
Permanently Wired or Cord Connected

GOODMAN COMPANY, L.P.
6151 SAN FELIPE, STE 500
HOUSTON, TX 77056



Intertek
3072079
CONFORMS TO UL-484
CERTIFIED TO
C22.2 NO. 117-1979



0240P04229