

Model No. EBBC - F060SB

Serial No. WFM057055

Improper indoor coil sizing or incorrect system charging can reduce system capacity and efficiency and may cause equipment damage.

These charging guidelines are for reference only for heat pumps. To properly charge heat pumps, the charge must be weighed in or out.

Charging Chart

Outdoor Temp. F°	Evaporator Suction Pressure - PSIG													
	72	74	76	78	80	82	84	86	88	90	92	94		
75	59	..	..	..	..	..	..	..	..	..	..	..	..	..
77	58	..	..	..	..	..	..	..	..	..	..	..	..	..
79	57	58	..	..	..	..	..	..	..	..	..	..	..	..
81	55	55	..	..	..	..	..	..	..	..	..	..	..	..
83	52	55	58	..	..	..	..	..	..	..	..	..	..	..
85	50	53	58	..	..	..	..	..	..	..	..	..	..	..
87	49	53	56	..	..	..	..	..	..	..	..	..	..	..
89	49	52	54	58	..	..	..	..	..	..	..	..	..	..
91	48	50	53	57	..	..	..	..	..	..	..	..	..	..
93	48	49	51	56	56	..	..	..	..	..	..	..	..	..
95	47	48	49	52	57	..	..	..	..	..	..	..	..	..
97	47	48	50	52	57	..	..	..	..	..	..	..	..	..
99	47	48	50	52	56	60	..	..	..	..	..	..	..	..
101	46	48	50	52	55	59	..	..	..	..	..	..	..	..
103	..	48	50	52	54	59	..	..	..	..	..	..	..	..
105	..	48	50	52	55	57	59	..	..	..	..	..	..	..
107	..	..	50	52	55	57	59	..	..	..	..	..	..	..
109	..	..	50	52	55	57	59	..	..	..	..	..	..	..
111	..	..	49	52	55	57	58	60	..	..	..	..	..	..
113	..	..	49	52	54	57	58	59	..	..	..	..	..	..
115	..	..	49	52	54	57	58	59	59	..	..	..	..	..

SPACERPAK®

MD006-01
Asset # 3105-AHU-1

01

T

JPACE[®] BLOWER COIL UNIT

Central Air - Anywhere
A WESTEK COMPANY

42-3094

MODEL

SERIAL NO.

ESP-4860V

AAQ-134

Max. Duct E.S.P. 1.5 I.W.C.
MOTOR IS THERMALLY PROTECTED

Motor H.P. 1

208/230 V.A.C., 60 Hz, 1 PH

Max. Fuse 10 Amps

Max. Circuit Breaker: 15 Amps

Designed For Use With Refrigerant 22

Max. Working Pressure 150 P.S.I.
Design Press. 300 P.S.I.G.

MEG. DATE

MANUFACTURED UNDER ONE OR MORE
OF THE FOLLOWING PATENTS:

U.S. 3,507,354 3,575,234 3,496,998

3,685,329 3,605,797 4,098,982

CANADA 891,1292 GREAT BRITAIN 1,254,023
A WESTEK CO. WESTFIELD, MA 01085