



CLOSED/SUMMER
OPEN/WINTER



Safgard[®]
SENSIT

LOW WATER CUT-OFF

MODEL 650P

**HYDROLEVEL
COMPANY**

NEW HAVEN, CT



LIMIT CONTROL
LISTED 4885

MINIMUM WATER LEVEL — 

9172

STEAM BOILERS
SHUT DOWN LOW WATER CUT-
OFF EVERY WEEK TO 10 DAYS
TO PREVENT EXCESSIVE
STEAM PRESSURE.

9163



ASSET # 15103

SENTRY MECHANICAL

MECHANICAL SYSTEM EVALUATION

1724 Leechburg Road
Pittsburgh, PA 15235
(412) 795-3040
Fax (412) 795-3206

Pages
of

One copy per piece of equipment

Date: 10-17-18

Job #: PM367

Customer Name: Army Reserve

Phone #:

Customer Contact: 10 Scenic Dr Washington PA

Job Location: PA 096-01

Equipment Type: Make: Peerless

Model #: 211A-08-W/S-I

Serial #: 211-13644-0998

Volts 115

Equipment Location: Boiler Rm

Equipment #: ASSET # 6645-Boiler-1

Area Served: Bldg

Filter(s) (qty., size & type):

Belt(s) (qty., size & type):

Accessibility:

Evaluation:

Low water cut out Hes water leaking from sensor

Gas vent line is corroded need replaced
about 3' section

Need

3- 1/2" Black iron nips 12"
1- 1/2" nip 6"
1- 1/2 x 1/2 x 3/8 Tee 1/2 - 1/2
1- 1/2 - 3/8 ell

Photos Attached: Yes ☐ No ☐

Status: Incomplete ☐ Complete ☐

Priority 1-5: ☐ (5 Being High)

Mark

Reviewed By:

Date:

Service Tech:

Date: