

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

INSPECTION, TESTING, AND CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 06 Mar 2018

Contractor Personnel on Site:

1. <u>Joshua D. Michael</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Work Performed:

Inspection, Testing, and Certification

W07192 W07193

1. <u>Backflow Prevention Testing (Qty 2) (Annual) Asset 1046 Asset 1061</u>
*1046 2. <u>*1 - Flomatic 3" RP2 SN# 00491 ch-1 8.1 ch-2 - 7.8 Relief. 5.5 psi</u>
3. <u>Static Pressure - 50 PSI shut-off valve #2 - closed</u>
*1061 4. <u>*2 Flomatic 1" RP2E SN# 07985 ch#1- 6.6 ch#2 - 7.0 Relief. 5.0 psi</u>
<u>Static pressure 50 PSI shut-off valve #2 closed</u>

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Joshua D. Michael Date: 06 Mar 2019

Signed: Josh D. Michael

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett, BSN Date: 20190306

Signed: Danielle Barrett

E-Mail: Danielle.e.Barrett.eiv@mail.mil

ASSE International

Reduced Pressure Principle Backflow Preventer (RP) ASSE Standard #1013 Field Test Report

Owner of Property US Army Corps Reserve Center

Address 1001 Oglebay Rd.

City Newark State DE Zip Code 19711

Occupant of Property (if different from owner) _____

Occupant Address _____

City _____ State _____ Zip Code _____

Manufacturer of Assembly: Flomatic Model #: RPZ

Size of Assembly: 1" Serial #: 67985

Location of Assembly and Equipment or System Application: 1st floor mechanical room

Test Equipment:

Manufacturer: Wilkins Model #: TG-5 Serial #: 893987

Calibration Date: Mar 2018

Date test was performed: 06 Mar 2019 Time test was performed: 145 Static Line Pressure: 50 psf

	Check Valve #2	Shutoff valve #2	Check Valve #1	Pressure Differential Relief Valve
Initial Test	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓) Pressure Drop Across Check Valve #1 18.1 psid	Opened at 50 psid
Describe parts and repairs when needed				
Final Test	Leaking () Closed Tight ()	Leaking () Closed Tight ()	Leaking () Closed Tight () Pressure Drop Across Check Valve #1 psid	Opened at psid

Certified Tester (print) Joshua D. Michael

Address 1150 Paddock Rd

City Smyrna State DE Zip 19977

Phone #: 302 659.1111

License #: DE 2241 Certification # 26486

Signature Joshua D. Michael Date: 06 Mar 2019

Comments or Recommendations (continue to other side, if needed): _____

Assembly Final Test Performance

Pass

Fail

DANFOSS FLOMATIC®
FLOMATIC VALVES

600
100

1/2" NPT
1/2" NPT
1/2" NPT
1/2" NPT