



# Backflow Prevention Assembly Test Report

Test Confirmation # **Unsubmitted**

Address: **900 ARMORY DR** Hazard ID: **3252685** Manufacturer: **Watts**  
 Company: **U S ARMY/COMD 99TH ARCOM** Meter #: **85359219** Model: **919QT**  
 Location: **Inside** Type: **RP**  
 Serial #: **18759** Size: **2.00**  
 Contact:

Reduced Pressure Principle Assembly				PVB/SVB
Double Check Valve Assembly				
<b>Initial Test</b>	<b>Check Valve #1</b>	<b>Check Valve #2</b>	<b>Relief Valve</b>	<b>AIR INLET</b>
05/14/19	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Did not Open <input type="checkbox"/>	Did not Open <input type="checkbox"/>
Pass Fail	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened at <input type="checkbox"/>	Opened at <input type="checkbox"/> PSID
<input checked="" type="checkbox"/> <input type="checkbox"/>	Held at <u>8.2</u> PSID	Held at <u>1.4</u> PSID	Opened at <u>2.2</u> PSID	<b>CHECK VALVE</b>
				Leaked <input type="checkbox"/>
				Held at <input type="checkbox"/> PSID
<b>Repairs</b>	Comments:			
	<input type="checkbox"/> Cleaned <input type="checkbox"/> Rubber Kit <input type="checkbox"/> Rebuild			
<b>Final Test</b>	<b>Check Valve #1</b>	<b>Check Valve #2</b>	<b>Relief Valve</b>	<b>AIR INLET</b>
	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>		Opened at <input type="checkbox"/> PSID
Pass Fail	Held at <input type="checkbox"/> PSID	Held at <input type="checkbox"/> PSID	Opened at <input type="checkbox"/> PSID	<b>CHECK VALVE</b>
<input type="checkbox"/> <input type="checkbox"/>				Held at <input type="checkbox"/> PSID
				Proper Shutoff <input checked="" type="checkbox"/>
				No 2 Shutoff <input type="checkbox"/>
				Service Restored <input type="checkbox"/>
				RV Exercised <input type="checkbox"/>
				Held Backpressure <input type="checkbox"/>
				Line PSI
Comments:				Meter Reading 0
<b>Cert. Tester</b> BOJAN MARTINOVICH(#40405)	<b>Company:</b>			
<b>Company Address:</b>				
<b>Test Kit:</b>	<b>Calibration Date:</b> 01/01/1900			



<a href="#">Main</a>	<a href="#">Add Test</a>	<a href="#">Review Unsubmitted Tests</a>	<a href="#">Payment Methods</a>	<a href="#">?</a>
----------------------	--------------------------	--	---------------------------------	-------------------

Your transaction has been successfully processed.

Checkout Receipt

Serial#	Description	Price
18759	900 ARMORY DR - Inside	\$17.00
Subtotal:		\$17.00
Total Paid:		\$17.00
Transaction Id: 41355507597		