

## 99th RSC Region 5, Zone Inventory

**Key:** Black - Current, **Blue** - Due, **Red** - Failed, **Yellow** - Added to Contract, **Grey** - Removed from Contract

<b>MD013 USARC Gaithersburg</b> <b>8791 Snouffers School Rd. Gaithersburg, MD 20879</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
1987	Boiler	Aerco	NB	CA MD013	10/29/2019	Yes	10/29/2020		
	Air Receiver	Steel Fab	NB	597167	10/29/2019	Yes	10/29/2022		
<b>MD016 USARC Upper Marlboro</b> <b>5550 Dowerhouse Rd. Upper Marlboro, MD 20772</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
	Boiler				10/22/2018	Yes	10/22/2019	Install nipple on low water control	
<b>MD020 USARC Riverdale</b> <b>6601 Baltimore Ave. Riverdale, MD 20737</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
1	Boiler					No		Replace Altitude Gage and install E-Stop	
2	Boiler					No		Replace Altitude Gage and install E-Stop	
<b>MD021 USARC Rockville</b> <b>1850 Baltimore Rd. Rockville, MD 20851</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
2096 (1)	Boiler	Weil-McLain	NB	CA #1 MD-021	10/28/2019	Yes	10/28/2020		
2095 (2)	Boiler	Weil-McLain	NB	CA #2 MD-021	10/28/2019	Yes	10/28/2020		
2094 (3)	Boiler	Weil-McLain	NB	CA #3 MD-021	10/28/2019	Yes	10/28/2020		
2097 (4)	Boiler	Weil-McLain	NB	CI4 MD-021	10/28/2019	Yes	10/28/2020		
	Air Receiver	Manchester	NB	500908	10/28/2019	Yes	10/28/2022		
<b>MD066 USARC White Plains</b> <b>Fox Tail Place White Plains, MD 20695</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
MD66-180 (Boiler 1)	Boiler	Camus	SN	011825971	10/25/2019	No		Building management wouldn't allow operation.	
MD66-181 (Boiler 2)	Boiler	Camus	SN	011825972	10/25/2019	No		Building management wouldn't allow operation.	
MD66-182 (Boiler 3)	Boiler	Camus	SN	011825972	10/25/2019	No		Building management wouldn't allow operation.	
	Boiler				11/15/2019				
	Air Receiver	Morganton	NB	705403	10/26/2019	Yes	10/26/2022		
<b>VA002 USARC Alexandria</b> <b>6901 Telegraph Rd. Alexandria, VA 22310</b>									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	
2176 (Boiler A)	Boiler	Burnham	SN	65179292	10/28/2019	No		Install E-Stop	
2177 (Boiler B)	Boiler	Burnham	SN	65179294	10/28/2019	No		Install E-Stop	
2178 (Boiler C)	Boiler	Burnham	SN	65179293	10/28/2019	No		Install E-Stop	