


W0# 5898 & 5899

Argent Inspections				
Form AI-08		Boiler Inspection Certificate		
Expiration Date 10/23/2018	Inspection Date 10/23/2018	Next Watersides/Firesides 2019/2019	Next Strength Test 0	National Board # CI Sectional MD
Customer USARC Riverdale MD-020		Manufacturer Weil-McLain		Year Built Unknown
Building # Boiler Room		Serial #		Property # Boiler #2
Pressure Allowed 50 psi	Capacity 1,557,000 BTU/HR	Safety Valves 1	Programmer Mfr Honeywell	Burner Mfr Weil McLain
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Heavy Fuel Oil <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Wood	
Commission # 13314	Inspector: Craig H. Bennett	Signature 		

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER