



OneCIS Insurance Company

95 Oakwood Rd
Lake Zurich, IL 60047
(855) 593-5115
www.us.bureauveritas.com

7/8/2019

44110-007209.00

USAR Center
295 Goucher St
Johnstown, PA 15905-3412

RE: Jurisdictional Inspection:
USAR Center
295 Goucher St
Johnstown, PA 15905-3412

Thank you for the consideration I received during my visit on June 10, 2019 at your facility listed above. The purpose of the visit was to perform the jurisdictional inspections of the objects listed below to determine compliance with jurisdictional laws and regulations. I was accompanied by Al Molinski Area Facility Operations Specialist, 703-738-5303, during my visit.

The inspections were performed on behalf of CMI Management, Inc. (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2008	Water Tube	PA-053 01	92346	None
2008	Water Tube	PA-053 02	90707	None
2008	Water Tube	PA-053 03	92357	None

Al Molinski and Scott Kender from SMI Mechanical Maintenance were present at the location during these inspections with the following observations were noted:

.
All three boilers previously had an outstanding violation of inoperability. SMI was able to get all three boilers operating and all 3 are now in good working order; all previous violations on all 3 boilers are now formally cleared.

As a result of these inspections 0 new recommendations were suggested.

Based upon this visit, OneCIS Operating Certificates for each boiler are being created and forwarded to the client.

The next inspection is tentatively scheduled to be completed by 06/2020.

Please contact me by phone at 724-396-5433 or by e-mail at joseph.klages@bureauveritas.com if there are any questions and to clear any recommendations.

Sincerely,

Joseph Klages

Joseph Klages
Jurisdictional Inspection Specialist

DISTRIBUTION

Cc:

CMI Management Inc.
Bernie Koblinsky
5285 Shawnee Rd Ste 510
Alexandria, VA 22312-2334
bernie.koblinsky@cmimgmt.com