

Anytime Plumbing and Drain Service
 410-300-5375/anytimeplumbing456r@gmail.com
 For All Your Backflow Needs

CROSS CONNECTION CONTROL REPORT

INVOICE # _____

Job Information				Date of Test			
Owner/Tenant Name		Address		Gauge of Calibration Date		Test Kit Used	
Southern Maryland United States Army Reserve		5550 Dowerhouse Rd, Upper Marlboro, MD 20772		10/09/17		TK-13G	
Gauge Information				Gauge Serial #			
P.O. #				464880			
Back Flow Test Information							
Manufacturer		Model		Manufacturer		Model	
Wilkins		975XL		Wilkins		975XL	
Size		Serial		Size		Serial	
3/4"		3251758		3/4"		329240	
Type		Relief		Type		Relief	
☒ RP2 ☐ DC		2.8		☒ RP2 ☐ DC		Failed	
(1) D.P.		(2) D.P.		(1) D.P.		(2) D.P.	
8.0		5.6		Failed		Failed	
Location		Location		Location		Location	
Mech Room		Mech Room					
ASSE #		ASSE #		ASSE #		ASSE #	
1013		1013					
Service		Service		Service		Service	
Domestic		Domestic		Domestic		Domestic	
Line Pressure		Line Pressure		Line Pressure		Line Pressure	
50		50		50		50	
Permit #		Permit #		Permit #		Permit #	
☒		Failed		☐		☐	
Pass		Pass		Pass		Pass	
Certification Information							
I hereby certify that I have the authority to make the foregoing report, that the report is correct, and that the tested Cross connection equipment will conform to the regulations in the current adopted local country codes.							
Signature of Inspector/Tester		Address		Name		Phone	
Michaela		7906 Spring Manor Drive, Greenbelt, MD 20770		Kevin Reece		410-300-5375	
Back Flow License #		Expiration Date		Email			
71755		12-19-18		Anytimeplumbing456r@gmail.com			