

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV022 Date of Visit: 4/22/2024

Contractor Personnel on Site:

1. <u>Midstate Plumbing</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 96526 WO# 15000

### Description of Repairs

Installed 3 new 2" water main shut off valves. Installed 15' of 2" copper main  
water line. Ran 10' of 1" boiler return line with hydronic fittings. Repaired multiple  
copper leaks on boiler. Radiator on air handler is broken/cracked. Needs replaced.

---

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Julie Pape Date: 4/30/2024

Signed: Julie Pape

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not  
constitute acceptance of any work performed by the contractor, it only acknowledges that the  
contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie Date: 5/1/2024

Signed: Jennifer A Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil

