

Tina Lee

From: Jon Milller <jmiller@bondwater.com>
Sent: Thursday, March 31, 2022 3:17 PM
To: Tina Lee; Mary Lowery
Cc: Richard Hicks; Adam Colopy; John Brown; Clinton Bates
Subject: [EXTERNAL]RE: DE007-04 Water Treatment March PM schedule WO 16782

CAUTION: This email has been received from outside of CMI - Use caution before clicking on links, opening attachments, or responding.

Tina,

All is well, I’m waiting for my 3rd child to be born soon, but have a little downtime. You should have the report for DE-007-04.

There is a fully functional chemical feed station for the cooling tower with a conductivity metering system. All equipment is working and was tested. My only concern is the glycol concentration may be low. Clinton Bates will be taking over this account as he has other accounts in the area. He’ll take a glycol sample, send it off to our lab and we’ll give you a report and show you what kind of shape that glycol is in.

Jon Miller, CWT
Account Manager
Bond Water Technologies
301-580-9820 (cell)

From: Tina Lee <Tina.Lee@cmimgmt.com>
Sent: Thursday, March 31, 2022 2:44 PM
To: Mary Lowery <Mary.Lowery@tideh2o.net>; Jon Milller <jmiller@bondwater.com>
Cc: Richard Hicks <richard.hicks@cmimgmt.com>; Adam Colopy <adam.colopy@tideh2o.net>; John Brown <john.brown@tideh2o.net>
Subject: RE: DE007-04 Water Treatment March PM schedule WO 16782

Hello Jon,

Hope all is well. Can I please get the Monthly report for DE007-04...Rick had also aske about the following:

Mary please schedule Jon from Bond to get out to DE007- 04 . Jon here’s a few things to look for : PM-WO# 16782 is for March ..
Jon please schedule this ASAP .

- This is a monthly PM for water treatment
- Is there a Chemical station installed like attached
- Is there a conductivity meter system installed .
- Any other equipment needed that I’m missing

Thanks
Tina

From: Mary Lowery <Mary.Lowery@tideh2o.net>
Sent: Thursday, March 10, 2022 8:26 AM
To: Jon Milller <jmiller@bondwater.com>
Cc: Richard Hicks <richard.hicks@cmimgmt.com>; Adam Colopy <adam.colopy@tideh2o.net>; John Brown <john.brown@tideh2o.net>; Tina Lee <Tina.Lee@cmimgmt.com>
Subject: DE007-04 Water Treatment March PM schedule WO 16782

CAUTION: This email has been received from outside of CMI - Use caution before clicking on links, opening attachments, or responding.

Ms. Barrett will not be in next week, and neither will her back up.

I am waiting to hear back from Jason and once I do I will let you know.

Thank you,
Mary Lowery
Project Coordinator
TIDEWATER, INC.

mary.lowery@tideh2o.net
6625 Selnick Drive, Suite A
Elkridge, MD 21075

 410-967-5346

From: Jon Milller <jmiller@bondwater.com>
Sent: Wednesday, March 9, 2022 2:24 PM
To: Mary Lowery <Mary.Lowery@tideh2o.net>
Cc: Richard Hicks <richard.hicks@cmimgmt.com>; Adam Colopy <adam.colopy@tideh2o.net>; John Brown <john.brown@tideh2o.net>; Tina Lee <Tina.Lee@cmimgmt.com>
Subject: [EXTERNAL]Re: [EXTERNAL]DE007-04 Water Treatment March PM schedule

CAUTION: External email, DO NOT click on any links/attachments unless you recognize the sender and know the content is safe

Hey Mary,

I’m looking at going out to DE-007-04 on Tuesday, 3/15 at 11 AM.....will that work for you all? Let me know when and if this is confirmed. thanks

Jon Miller, CWT
Account Manager
Bond Water Technologies
301-580-9820

On Mar 3, 2022, at 3:32 PM, Mary Lowery <Mary.Lowery@tideh2o.net> wrote:

Jon,

Please let me know your availability and I will get this scheduled.

Thank you,
Mary Lowery
Project Coordinator
TIDEWATER, INC.

mary.lowery@tideh2o.net
6625 Selnick Drive, Suite A
Elkridge, MD 21075

 410-967-5346


From: Richard Hicks <richard.hicks@cmimgmt.com>
Sent: Thursday, March 3, 2022 3:31 PM
To: Adam Colopy <adam.colopy@tideh2o.net>; Mary Lowery <Mary.Lowery@tideh2o.net>; John Brown <john.brown@tideh2o.net>
Cc: Jon Milller <jmiller@bondwater.com>; Tina Lee <Tina.Lee@cmimgmt.com>
Subject: [EXTERNAL]DE007-04 Water Treatment March PM schedule

CAUTION: External email, DO NOT click on any links/attachments unless you recognize the sender and know the content is safe

Mary , Jon ,

Mary please schedule Jon from Bond to get out to DE007- 04 . Jon here’s a few things to look for : **PM-WO# 16782 is for March** .. Jon please schedule this ASAP .

- This is a monthly PM for water treatment
- Is there a Chemical station installed like attached
- Is there a conductivity meter system installed .
- Any other equipment needed that I’m missing

Work Order	Description	Site	Location /
16782		=99REG5	
<u>16782</u>	PMM-OY4-243 PM Monthly Water Treatment DE007-04 99REG5		DE007-04
<input type="checkbox"/> <i>Select Records</i>			

Thanks,
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301
Richard.Hicks@cmimgmt.com