

Tuesday, August 31, 2021 3:23 PM EDT

Tidewater, INC
 MD-019
 12100 Greenspring Ave
 Owings Mills MD 21117-1610
 (410) 540-8700

Report Number: 371822
 Recorded By: Bill Herring
 (443) 721-0698
 bherring@bondwater.com

MD-019 - Closed Loops

Test	Hot Loop	Chilled Glycol Loop		
Conductivity (as mmhos)	1040 3500 max	2295 3500 max		
pH	8.3 8 - 10.5	8.5 8 - 10		
Molybdate (ppm as Mo)	250 50 - 200	80 50 - 200		

Opening Comment

SFC William Schaffer provided access into and out of the boiler room today.

Hot Water Loop

Online 

Performed all tests for hot water loop. All readings were within desired range, providing plenty of corrosion protection.

Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol loop. All readings were within desired range, providing optimal corrosion protection. A glycol sample was collected today and sent for a lab test.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.