

CMI Management
VA 002
6901 Telegraph Rd
Alexandria VA 22310
(202) 437-5119

Recorded By: **Marshall Kohne**
(301) 721-2663
mkohne@bondwater.com

Boiler Room - HVAC Equipment

Test	Dual Temp Loop			
Conductivity (as mmhos)	4642 5000 max			
Molybdate (ppm as Mo)	190 50 - 200			
pH	8.0 8 - 10.5			

Dual Temperature Closed LoopOnline 

All readings indicate good levels of protection for closed system. I also changed the filter in the system.