

Annual Test & Maintenance Report for Backflow Prevention Assemblies

Facility Name: USARC WV010
Contact Person: JENNIFER BAILE

Address: Rt 2 Box 77 Clarksburg WV
Phone No. 724-544-5252

Assembly Information

Make: WATTS
Model: 909
Size: 2"
Serial Number: 294144

Installation Information

Containment Isolation
Meter Pit Basement Floor Number:
Penthouse Boiler Room Room Number:
Mechanical Room Protection Provided:

Double Check Assembly

Initial Test	Outlet Valve		Pass Fail
	1 st Check Valve	__psid	Pass Fail
Date	2 nd Check Valve	__psid	Pass Fail

Reduced Pressure Assembly

1 st Check Valve	<u>8</u> psid	Pass Fail
Relief Valve Opening Point	<u>3</u> psid	Pass Fail
2 nd Check Valve		Pass Fail
Outlet Valve	<u>Pass</u>	Fail

Pressure Vacuum Breaker

Air Inlet Valve	__psid	Pass Fail
Check Valve	__psid	Pass Fail

Repairs & Materials Used

Double Check Assembly

Re-Test After Repairs	Outlet Valve		Pass Fail
	1 st Check Valve	__psid	Pass Fail
Date	2 nd Check Valve	__psid	Pass Fail

Reduced Pressure Assembly

1 st Check Valve	__psid	Pass Fail
Relief Valve Opening Point	__psid	Pass Fail
2 nd Check Valve		Pass Fail
Outlet Valve	Pass	Fail

Pressure Vacuum Breaker

Air Inlet Valve	__psid	Pass Fail
Check Valve	__psid	Pass Fail

TESTER CERTIFICATION: I certify that the above data is correct and that the backflow prevention device is in proper working condition.

Tester Name (Printed) RAY KYCZEK Signature Ray Kycek
Phone Company Name CASIO TECHNICAL WV Cert. No. 31072 Date 3-13-18

FACILITY CERTIFICATION: I hereby certify that the above backflow prevention device has been in constant use at this location during the entire prescribed interval between test periods and during that period this device was not-bypassed, made inoperative or removed without proper authorization. I further certify that I have the authority and responsibility to ensure the above.

Owner/Officer (Printed) LT Flougher, Christopher Signature Ulf F Phone No. 304-592-3965
Title: Operations Officer Date: 13 MAR 18 1004

Return White Copy With \$ fee to:

Phone
Fax: