

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa193MECHANIC
SIGNATURE: DATE: 8-6-19LOCATION/RM #: Hallway WO# 9486 ASSET # 4599START TIME: 10:30FINISH TIME: 10:35


CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa193MECHANIC
SIGNATURE: DATE: 8-6-19LOCATION/RM #: Hallway WO# 9486 ASSET # 4599START TIME: 10:30 FINISH TIME: 10:35

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

2

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stairwell WO# 9486 ASSET # 4598

START TIME: 10:20

FINISH TIME: 10:25

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		


Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **UNIT HEATER, ELECTRIC**

SITE AND BLDG #: Pa193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stairwell WO# 9486 ASSET # 4598

START TIME: 10:20

FINISH TIME: 10:25

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		


Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stairwell WO# 9486 ASSET # 4598

START TIME: 10:20

FINISH TIME: 10:25

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	✓		
2	Clean heating coil. Brush vacuum where accessible.	✓		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	✓		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	✓		
6	Verify proper control by modulating the thermostat through complete cycle.	✓		
7	Inspect unit for proper operation.	✓		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stairwell WO# 9486 ASSET # 4598

START TIME: 10:20

FINISH TIME: 10:25

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

2

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa 193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stratwell WO# 9486 ASSET # 4597

START TIME: 10:15

FINISH TIME: 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **UNIT HEATER, ELECTRIC**

SITE AND BLDG #: Pa-193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stratwell WO# 9486 ASSET # 4597

START TIME: 10:15

FINISH TIME: 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		


Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa-193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Staffwell WO# 9986 ASSET # 4597

START TIME: 10:15

FINISH TIME: 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	☒		
2	Clean heating coil. Brush vacuum where accessible.	☒		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒		
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒		
6	Verify proper control by modulating the thermostat through complete cycle.	☒		
7	Inspect unit for proper operation.	☒		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒		


Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST UNIT HEATER, ELECTRIC

SITE AND BLDG #: Pa 193

MECHANIC
SIGNATURE: 

DATE: 8-6-19

LOCATION/RM #: Stratwell WO# 9486 ASSET # 4597

START TIME: 10:15

FINISH TIME: 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check heater coils and associated piping for leaks or corrosion.	☒			
2	Clean heating coil. Brush vacuum where accessible.	☒			
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	☒			
4	Inspect fan for bent blades, unbalance, excessive noise and vibration.	☒			
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	☒			
6	Verify proper control by modulating the thermostat through complete cycle.	☒			
7	Inspect unit for proper operation.	☒			
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	☒			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

x