



## ENERGY MANAGEMENT TECHNOLOGIES, LLC

5 HEMLOCK STREET

LATHAM, NEW YORK 12110

518.783-7810

FAX: 518.783-2079

June 19, 2019

CMI Management  
Attn: Steve Miller

### Original CSS# 16895 – Rotterdam USARC

**Subject:** Quote to install new recirculating loop return from the ladies room bath to the new DHW tank at the Rotterdam site. The system is missing a return line which is dead heading the pump when a faucet is not opened. We will also replace the existing 40 feet of galvanized piping the feeds the ladies room.

#### SCOPE OF SERVICE:

- Remove 40 feet of 1" galvanized and replace with ¾" copper.
- Install new loop return from end of loop in ladies room back to the DHW tank tempering valve
- Insulate return line
- Program time clock on pump to turn off at night
- Fill system and test operation and set tempering valve to maintain 120 degrees

***The price for the above work: \$5,882.00.....Five Thousand Eight Hundred Eighty Two Dollars.***

Cost Breakdown: Labor (35 Hrs. @ \$108) \$3,780.00 and Materials/shipping \$2,102.00

***Any and all taxes are not included.***

If you have any questions, please contact me Office 518-783-7810 Cell 518-937-0770.

Sincerely,

*David O'Connor*

Special Projects Manager

**ENERGY MANAGEMENT TECHNOLOGIES, LLC**

**5 Hemlock Street**

**Latham, New York 12110**

#### CUSTOMER ACCEPTANCE:

NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_

DATE: \_\_\_\_\_