



ENERGY MANAGEMENT TECHNOLOGIES, LLC

5 HEMLOCK STREET

LATHAM, NEW YORK 12110

518.783-7810

FAX: 518.783-2079

PROPOSAL

December 5, 2019

CMI Management
Attn: Joe Bayne

Original CSS# 18784
EMTech# 4839

Subject: Heat Pumps Communication

Scope of Service:

EMTech proposes to supply all labor and material needed to complete the following

- Inspect Heat Pumps
- HP 2-28: Water supply valve stuck. Unthread and oil.
- HP 2-26: Low on Nitrogen, charge. Locate leak – will provide separate proposal
- HP 2-33: Bad fan relay – replace
- Test operation

For the above work, we quote: \$1,127.05.....One Thousand One Hundred Twenty Seven Dollars and Five Cents.

Any and all taxes are not included.

The above is broken down as follows: **\$1,080.00 Labor**
 \$47.05 Materials

Thank you for continuing to include EMTech on your energy team. As always, we look forward to working with you. Please feel free to contact for any questions or concerns you may have on this project.

Sincerely,

Jenna Caligaris
Service Coordinator