

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: _____	MECHANIC SIGNATURE: _____	
LOCATION/RM #: _____	DATE: _____	
WO# _____	ASSET # _____	START TIME: _____
FINISH TIME: _____		

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check physical condition of feeder. Clean and/or repair as needed.			
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: