

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST CONDENSATE PUMP

SITE AND BLDG #: _____

**MECHANIC
SIGNATURE:** _____

DATE: _____

LOCATION/RM #: _____ **WO#** _____ **ASSET #** _____

START TIME: _____ **FINISH TIME:** _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Wash and clean pump. If pump is used in a dirty environment or is pumping something other than clear condensate water, the tank should be removed and cleaned.			
2	Pour enough water into the tank to activate the pump.			
3	Ensure that the pump is in proper working condition. Recommend repair or replacement as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: