



WORK ESTIMATE

CSS #: 18544

Work Order #: 8449

Emergency ☐

Urgent ☒

Routine ☐

Company Name:	CMI	Facility ID:	MD016
Contractor POC:	Rick Hicks		
Telephone No:	703-738-5301	Building/Location; (e.g., Classroom/Room #)	Mechanical room
E-Mail Address:	Richard.hicks@cmimgmt.com		
Assigned Technician(s):	Patrick Donovan	4/3/2019	

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

.. 4/3/19 will return for follow up we have KO approval -4/3/19- Patrick replaced air filters in AHU that got wet .Installed 20x25x2 New filters and got AHU ready to run and worked with S&S mechanical

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Onsite support Labor -Patrick x \$80 per hour			4	\$320.00
Graingers filter cost		\$24.17	0	\$24.17
Sales Tax			0	
Diagnostic Labor			0	
SUB-TOTAL COSTS:	Materials Total	\$24.17	Labor	\$320.00
TOTAL			\$344.17	