



Mechanical HVAC Service Contractors

HVAC

Phone: (518) 326-8450 · Fax: (518) 326-8435
P.O. Box 311, 95 Hudson River Road
Waterford, New York 12188Job # 18125

UNIT	MAKE	MODEL	SERIAL #	VOLTS	ENVIRONMENTAL CHECKLIST		
NAME Schenectady Army Reserve	STREET			DATE <u>4-19-22</u>	CONDENSING UNIT	QTY.	TYPE/DISPOSITION
CITY					<input type="checkbox"/> RECOVERED		
TECHNICIAN					<input type="checkbox"/> RECYCLED		
DESCRIPTION OF WORK PERFORMED					<input type="checkbox"/> RECLAIMED		
					<input type="checkbox"/> RETURNED		
					<input type="checkbox"/> DISPOSAL		
<input type="checkbox"/> COOLING OUT <input type="checkbox"/> HEATING OUT <input type="checkbox"/> LEAK <input type="checkbox"/> WARRANTY <input type="checkbox"/> INSTALLATION							
For HD 1-11 off on low R. Reset. Started pump Right into low psi alarm Leak check refrigerant CRKT, no leaks found will quote a fix with CMI							
RECOMMENDATIONS							
ITEM	DESCRIPTION	UNITS	AMOUNT	QTY	DATE	NAME	TYPE
REFRIGERANT R-	LBS.			3	<u>4-19-22</u>		111-
FILTERS	X	X					
1	Trip Charge		50 -				
TOTAL MATERIALS						TOTAL LABOR	

CUSTOMER SIGNATURE

DATE 4-19-22

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY060

Date of Visit: 4-19-22

Contractor Personnel on Site:

1. MIC 1
2. _____
3. _____
4. _____
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. N/A
2. _____
3. _____
4. _____

Inspection, Testing, and Certification

1. N/A
2. _____
3. _____
4. _____

Other Recurring Services

1. N/A
2. _____
3. _____
4. _____

Service Calls -- Service Call Number and Description

1. 055#34700, fan HP 1-11 low on charge
2. Leak checked, no leaks found. will quote fix.
3. _____