

DRISTEEM
HUMIDIFIER COMPANY

A SUBSIDIARY OF RESEARCH PRODUCTS CORPORATION

14949 Technology Drive
Eden Prairie, MN 55344 USA

1-800-328-4447
Fax 952-229-3200

www.dristeen.com

Conforms to UL Std 998
Certified to CAN/CSA Std C22.2 No. 104

more of the following
patents: 4,564,746
4,879,902 5,000,765
5,099,823 5,126,080
5,199,486 RE 33414



Recognized
Component



9700549

VAPORMIST® Humidifier

Serial No./No. De Serie/
Seriennummer/No. De Serie: 1106216-01-01
Model/Modele/Modell/Modelo: VM99-8
Voltage: 480V
Phase: 3~
Hertz: 50/60 Hz
Amperage: 14.4A
Control Voltage/Tension de
Regulation/Stenerspannung/
Voltaje de maniobra: 24V, 50/60HZ, 15W
VL Program Code: EM1100024A700X
Date/Date/Datum/Fecha: 11/04/02

MINIMUM/MAXIMUM SUPPLY WATER PRESSURE

EAU D'ALIMENTATION

WASSERDRUCK ZULAUF

PRESION DE SUMINISTRO DE AGUA

MIN:

MAX:

MINI/MIN:

MAXI/MAX:

25 PSI
80 PSI
172.5 KPA
552.0 KPA

DANGER! VERY HOT WATER - DRAIN WATER BEFORE SERVICING

DANGER! EAU TRES CHAUDE - VIDANGER AVANT L'ENTRETIEN

ACHTUNG! SEHR HEISS WASSER. VOR WARTUNGSARBEITEN

WASSER ABLASSEN

ATENCIÓN! PELIGRO POR AGUA CALIENTE. DRENAR ANTES DE SERVIR.

R-+
W-

MECHANICAL SYSTEM EVALUATION
One copy per piece of equipment

Pages _____ of _____

Date: _____

Customer Name: (MI) JOHNSTOWN
Address: 284 Aviation Rd
Job Location: JOHNSTOWN
Equipment Type: STEAM HUMID
Model #: VM99-8
Volts: 480
Equipment #: ASSET 5059
Filter(s) (qty, size & type): N/A
Bell(s) (qty, size & type): N/A
Accessibility: Good
Evaluation: HEATER PROBES AND WHITE FILL LEVEL
SENSORS NEEDS REPLACED GASKETS FOR THESE
PARTS ALSO NEED REPLACED

Customer Contact: _____
Phone #: _____
Job #: PM352

Make: DRISTEEM
Serial #: 1106216-01-01
Equipment Location: BAYLOR RM
Area Served: OFFICES

Reviewed By: _____
Service Tech: _____
Date: 5/16/19

WHITE - Service Department
YELLOW - Job File
PINK - Technician