

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA055 Date of Visit: 29 JAN 19

Contractor Personnel on Site:

1. _____
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 16712 WO# 7519

Description of Repairs

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Darren Young Date: 1-29-19

Signed: Darren Young

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Timothy S Peters Date: 29 JAN 19

Signed: Timothy S Peters

E-Mail: _____

Michele Gray

From: 99R4 Service <99R4.Service@cmimgmt.com>
Sent: Friday, January 25, 2019 4:07 PM
To: Michele Gray
Cc: Joe Bayne; Bernie Koblinsky
Subject: Urgent Service call. WO 7519, CSS 16712, PA055-01

Michele,

WO 7519 CSS 16712- PA055- Urgent- Repair Trane MAU1 - Asset #3419 - Unit not responding to BAS commands. Unit services the kitchen area. Programmed for unoccupied to 55 degrees, space temp of 46 degrees, supply air temp of 29 degrees. BAS says blower is running but in actuality it is not. Checked all breakers, fuses, etc. Unable to restore operation at user level.

Michele DuBois
Service Desk / 99th - Region 4
5285 Shawnee Road Suite #510
Alexandria, VA 22312
703-738-5307