

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _VA001_____ Date of Visit: ___7-19-18_____

Contractor Personnel on Site:

1. ___1_____ 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# _____

Service Calls – Service Call Number and Description

1. CSS# _____ 14683 found compressor on unit grounded and bad Compressor needs replaced. _____
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: _Stacy Duty_____ Date: ___7-19-18_____

Signed: _____

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: _Vickie Bennett___GS09_____ Date: ___7-19-18_____

Signed: _____

E-Mail:

___vickie.l.bennett.civ@mail.mil_____

Capeland® Scroll
Advanced Scroll Temperature Protection
Compressor May Stop Pumping With Motor Running. Turn Off And Wait Until Cool. May Need More Than 1 Hour To Reset.
Este compresor puede dejar de comprimir, aun con el motor funcionando. Apaguelo y espere a que se enfríe, hasta que la protección interna se vuelva a cerrar (reestablecer). Puede requerir mas de una hora para restablecerse.
103 0366-01 www.EmersonClimateContractor.com/ASTP



