

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: P-003 Date of Visit: 4/4/19

Contractor Personnel on Site:

- | | |
|-------------------------------|------------------------------|
| 1. <u>Tony</u> <u>Granus</u> | 4. <u>Scott</u> <u>Werry</u> |
| 2. <u>Jim</u> <u>Geertsen</u> | 5. _____ |
| 3. <u>Gary</u> <u>Beitzel</u> | 6. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

- | | |
|----------------|-------|
| 1. <u>8252</u> | _____ |
| 2. <u>8301</u> | _____ |
| 3. _____ | _____ |
| 4. _____ | _____ |

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertsen Date: 4-4-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Bird Keith Date: 20190404

Signed: [Signature]

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 003-01 Date of Visit: 4/4/19

Contractor Personnel on Site:

- | | |
|-------------------------|-----------------------|
| 1. <u>Tony Lorenz</u> | 4. <u>Scott Werry</u> |
| 2. <u>Jim Geertgens</u> | 5. _____ |
| 3. <u>Guy Batzel</u> | 6. _____ |

Work Performed:

Other Recurring Services

- | | |
|-----------------|-------|
| 1. <u>836 f</u> | _____ |
| 2. _____ | _____ |
| 3. _____ | _____ |
| 4. _____ | _____ |

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 4-4-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Brad Keitel Date: 20190404


Signed: [Signature]

E-Mail: _____

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
THERMOSTATS**

SITE AND BLDG #:

PA 003-02

MECHANIC
SIGNATURE:


DATE:

4/4/18

LOCATION/RM #:

8ms

WO#

8351

ASSET #

5989

START TIME:

945

FINISH TIME:

950

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		—	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		—	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		—	
2	Review all zone set points at the server.	—		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	—		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	—		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	—		
6	If applicable, replace battery as needed.		—	

Note: The technician shall perform any repairs identified during PM. If a repair is needed, the technician shall provide a written estimate of the cost of the repair and obtain approval from the building manager before proceeding with the repair.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

/

Pc

Digital

300

Photo

76

69.2

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
THERMOSTATS

SITE AND BLDG #:

PA 003 -02

MECHANIC
SIGNATURE:

DATE: 4/4/18

LOCATION/RM #:

OMS WO# 6122 ASSET # 6122

START TIME:

9:45

FINISH TIME:

9:55

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		✓	
2	Review all zone set points at the server.	✓		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	✓		
6	If applicable, replace battery as needed.		NA	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

1 PC DISIRME
72 71.6