

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: P1 011

Date of Visit: 3-8-19

Contractor Personnel on Site:

1. Tony Cazaros
2. Jim Geertgens
3. Scott Burch

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 7688
2. 7771
3. 7991
4. 7820

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 3-8-19

Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: De la Cruz Ramon E. Date: 2019 03 08

Signed: De la Cruz Ramon E.

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: 8001

Date of Visit: 3/8/19

Contractor Personnel on Site:

1. Tony (Crew)
2. Jim Geertgens
3. Scott (Crew)

- 4.
- 5.
- 6.

Work Performed:

Other Recurring Services

1. 7619
- 2.
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 3-8-19
Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: De la Cruz Ramon E. Date: 20190308
Signed: Ramón E. De la Cruz

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: *P-011-42*LOCATION/RM #: *005*WO# *7820*ASSET # *8058*MECHANIC
SIGNATURE: *[Signature]*DATE: *3/5/19*START TIME: *1015*FINISH TIME: *1030*

ITEM #	DESCRIPTION	SPECIAL INSTRUCTIONS	BASIC COMPLETION		NOTES/ACTIONS (IF BASIC COMPLETION NOT MET, PROVIDE EXPLANATION)
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Start and stop fan with local switch				
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.				
3	Inspect, adjust belts and pulleys. Replace belt as needed.				
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.				
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.				
6	Clean fan as needed.				
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.				
8	Repair as needed				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes: