

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PF 001-01 Date of Visit: 6/7/19

Contractor Personnel on Site:

1. Tony Lanza
2. Jim Geertsen
3. _____
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 9237
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertsen Date: 6-7-19

Signed: Jim Geertsen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT DelaCruz Date: 6/7/19

Signed: Zachary C

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Poc 11 Date of Visit: 6/7/19

Contractor Personnel on Site:

1. Tony Goren
2. Jim Gentgens
3. _____
4. _____
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1.	<u>9149</u>	<u>9086</u>
2.	<u>9272</u>	<u>9338</u>
3.	<u>9313</u>	<u>9451</u>
4.	<u>9379</u>	

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Gentgens Date: 6-7-19

Signed: Jim Gentgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sgt De La Cruz Date: 6/7/19

Signed: Sgt De La Cruz

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #:

P-011-02

MECHANIC
SIGNATURE:

DATE:

6/2/18

LOCATION/RM #:

WO# 7451

ASSET # 4263

START TIME:

1040

FINISH TIME:

1100

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/	/	
2	For gsa/oil heaters:			
3	1. Remove access panels if applicable.	/	/	
4	2. Check the fire box liner or refractory for cracks and leaks.	/	/	
5	3. Check all gas lines for leaks. Repair as needed.	/	/	
6	Clean dirt from heater, vacuuming is preferred.	/	/	
7	Check operation of gas valve.	/	/	
8	Check for gas leaks.	/	/	
9	Check operation of thermostat.	/	/	
10	If applicable, replace primary air intake filter.	/	/	
11	As needed, clean spark electrode and reset gap, replace if necessary.	/	/	
12	Inspect flue pipe and connections.	/	/	
13	If applicable, inspect and clean outside air blower and blower intake.	/	/	
14	Inspect unit for proper operation.	/	/	
15	Inspect unit for overall condition and recommend for replacement or other needed repairs.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: P1011 -02

MECHANIC
SIGNATURE:

LOCATION/RM #: WO# 9417 ASSET # 4264

DATE: 6/11/18

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
3	For gsa/oil heaters:			
4	1. Remove access panels if applicable.	/		
5	2. Check the fire box liner or refractory for cracks and leaks.	/		
6	3. Check all gas lines for leaks. Repair as needed.	/		
7	2. Clean dirt from heater, vacuuming is preferred.	/		
8	3. Check operation of gas valve.	/		NA
9	4. Check for gas leaks.	/		
10	5. Check operation of thermostat.	/		
11	6. If applicable, replace primary air intake filter.	/		efr
	7. As needed, clean spark electrode and reset gap, replace if necessary.	/		NA
	8. Inspect flue pipe and connections.	/		NA
	9. If applicable, inspect and clean outside air blower and blower intake.	/		
10	10. Inspect unit for proper operation.	/		
11	11. Inspect unit for overall condition and recommend for replacement or other needed repairs.	/		VA

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For

cracked heat exchanger

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: P 6/1 - 01

MECHANIC
SIGNATURE: 

DATE: 6/6/15

LOCATION/RM #: WO# 9457 ASSET # 4265

START TIME: 1145

FINISH TIME: 1200

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
2			✓	
3	For gsa/oil heaters:			
4	1. Remove access panels if applicable.		✓	
5	2. Check the fire box liner or refractory for cracks and leaks.		✓	
6	3. Check all gas lines for leaks. Repair as needed.		✓	
7	Clean dirt from heater, vaccuming is preferred.		✓	
8	Check operation of gas valve.		✓	NA
9	Check for gas leaks.		✓	NA
10	Check operation of thermostat.		✓	NA
11	If applicable, replace primary air intake filter.		✓	NA
	As needed, clean spark electrode and reset gap, replace if necessary.		✓	NA
	Inspect flue pipe and connections.		✓	NA
	If applicable, inspect and clean outside air blower and blower intake.		✓	NA
	Inspect unit for proper operation.		✓	
	Inspect unit for overall condition and recommend for replacement or other needed repairs.		✓	NA

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For

clacked heat exchanger