

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PR003

Date of Visit: 9/3/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Beertgens
3. Scott Jerry

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. 10797
2. 10832
3. 10921
4. 10837

10945

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Beertgens Date: 9-3-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sgt Date: 3 Sept 17

Signed: 

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PR 013 - 01to2 Date of Visit: 9/3/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geertges
3. Scott Werry
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 10731
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertges Date: 9-3-19

Signed: Jim Geertges

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sgt 1st Date: 2-3-19

Signed: A. A.

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR PACKAGED UNIT/ROOF TOP UNIT (RTU)

SITE AND BLDG #:

P-013 - 01

MECHANIC
SIGNATURE:

9/3/19

LOCATION/RM #:

001514

WO# 16921 ASSET # 4718

DATE:

START TIME:

830

FINISH TIME: 845

ITEM #	CHECKPOINT DESCRIPTION	BASED ON CHECKLIST		NOTES/ACTIONS (INCLUDES COMMENTS, CORRECTING, PROVIDED INFORMATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work		/	
1	Thoroughly inspect and clean interior and exterior of machine with wet/dry vacuum, (remove panels)	/		TO BE PERFORMED AT EACH INSPECTION SERVICE
2	Clean drain pan and note excessive corrosion. Treat rusted areas with rust inhibitor. Ensure that the rust inhibitor chemical does not add volatile organic compounds or contaminants to the drain pan. If possible, rinse well after application or choose a less hazardous material. Consult the chemicals Safety Data Sheet (SDS) for this information		/	
3	Check for refrigeration leaks on all lines, valves, fittings, coils, etc., using a halogen leak detector or similar testing device. If leaks are not able to be stopped or corrected, report leak status to supervisor.		/	
4	Check condition of cooling and reheat coils. Use fin comb if need to straighten fins.		/	
5	Clean coils. Use detergent solution and warm water if coil is heavily soiled.		/	
7	Clean and lubricate motor and squirrel cage fan(s). Check alignment of motor and fan. Check bearings for excessive wear.		/	
8	Check belt tension and condition. Adjust or replace as required.		/	
9	Replace pre-filters if needed.		/	
10	Replace final filter if needed.		/	
11	If applicable confirm the following: i. Humidistat activates humidifier. ii. Reheat coils activate properly. iii. Discharge air temperature is set properly.		/	
12	Check and adjust vibration eliminator mountings if equipped. Repair or replace if required		/	
13	If applicable, clean and test condensate pump and alarm.		/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Roof top

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: Pa Q13 -61
 LOCATION/RM #: OUTSIDE WO# 10921 ASSET # 5173

MECHANIC
SIGNATURE:

DATE:

8/3/19

START TIME:

8:15

FINISH TIME:

8:30

CHECK POINT	CHECKPOINT DESCRIPTION	SPECIAL INSTRUCTIONS	TASK COMPLETED		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO PROVIDE EXPLANATION)
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule outage of unit with personnel in area the unit serves.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.				
2	Wash coil with coil cleaning solution - Rinse Thoroughly				
3	Straighten fin tubes with fin comb, as needed.				
4	Check electrical connections for tightness.				
5	Check mounting base for tightness.				
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.				
7	Inspect all piping for leaks and tighten loose connections.				
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.				
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.				
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.				
11	Clean up work area.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #:


Pr 013-01

LOCATION/RM #:

112

WO# 10921

ASSET # 5185

MECHANIC
SIGNATURE:


DATE:

8/3/19

START TIME: 800

FINISH TIME: 810

NOTES/ ACTIONS
IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	
2	Schedule shutdown with operating personnel, as needed.	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/	
1	Check fan blades for dust buildup and clean if necessary	/	
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	/	
3	Tighten all electrical connectors to proper torque as needed.	/	
4	Check that the fan runs properly in all speeds as applicable.	/	
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/	
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	
7	Lubricate mechanical connections of dampers sparingly as applicable.	/	
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/	
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/	
10	Check coils for leaking, tightness of fittings.	/	
11	Use fin comb to straighten coil fins as needed.	/	

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes:

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: P00013-01

LOCATION/RM #: 118

WO# 10921

ASSET # 5189

MECHANIC
SIGNATURE: *John*

START TIME: 8:00

DATE: 8/3/19

FINISH TIME: 8:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS
			(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	
2	Schedule shutdown with operating personnel, as needed.	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/	
1	Check fan blades for dust buildup and clean if necessary.	NP	
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	NP	
3	Tighten all electrical connectors to proper torque as needed.	/	
4	Check that the fan runs properly in all speeds as applicable.	/	
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/	
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	
7	Lubricate mechanical connections of dampers sparingly as applicable.	NP	
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	NP	
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/	
10	Check coils for leaking, tightness of fittings.	/	
11	Use fin comb to straighten coil fins as needed.	/	

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

NP

NP



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker
Additional Notes:

B/C

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: *PA 013 - 01*LOCATION/RM #: *0-1512* WO# *10921* ASSET # *5223*MECHANIC
SIGNATURE: *[Signature]*DATE: *8/3/19*START TIME: *8:20*FINISH TIME: *8:30*

CHECK POINT	CHECKPOINT DESCRIPTION	SPECIAL INSTRUCTIONS	TASK COMPLETED		NOTES/ACTIONS (IF TASK NOT COMPLETED, CHECKED NO PROVIDED EXPLANATION)
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule outage of unit with personnel in area the unit serves.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.				
2	Wash coil with coil cleaning solution - Rinse Thoroughly				
3	Straighten fin tubes with fin comb, as needed.				
4	Check electrical connections for tightness.				
5	Check mounting base for tightness.				
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.				
7	Inspect all piping for leaks and tighten loose connections.				
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.				
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.				
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.				
11	Clean up work area.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHILLER CONTROL PANEL (ANNUAL)

ACTIVITY AND BLDG #: PA 013 - C1

LOCATION: *Basin* *new* WS# 10921 Asset # 5321MECHANIC
SIGNATURE: *John*

DATE: 9/3/19

START TIME: 750

FINISH TIME: 753

CHECK	DESCRIPTION	CHECK (GIVEN/DETERMINED)	DARK (COMPLETED)		NOTES/ACTIVITIES
			YEST	TON	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Read and understand the manufacturer's instructions before making any adjustments or calibrations.				
4	Schedule work with operating personnel, as needed.				
5	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
6	Ensure appropriate site personnel are notified that alarms that may result from testing and to disregard them until testing is completed.				
7	Replace defective control safeties (as work order) found while performing preventive maintenance.				
JOB PERFORMED DATE EACH INSPECTION SERVICE					
1	Clean and calibrate all controlling instruments (temperature and pressure transducers, etc.) in accordance with manufacturer's instructions and maintenance standard.				
2	Check and clean all electrical contacts and pneumatic orifices.				
3	Check pneumatic tubing for leaks or damage. Repair or replace as required.				
4	Check for bad indicator lights and gauges and replace as necessary.				
5	Test all controllers and set at proper set points.				
6	Check operating data and analyze for proper operation. Note unusual conditions such as compressor surge on maintenance log.				

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- General Services Administration (GSA) Public Building Service. 2012. *Public Buildings Maintenance Standards Final*. October 1.

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at [\(Provide Link to OEM Manual/Asset Library\)](#)

Additional Notes:

HVAC Control Panel

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHILLER CONTROL PANEL (ANNUAL)

ACTIVITY AND BLDG #:

P1 013-01

LOCATION: *Boiler* w# 16921 asset # 1322MECHANIC
SIGNATURE: *Johnston*

DATE: 8/3/19

START TIME: 815

FINISH TIME: 820

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETED		NOTES/ACTIONS
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Read and understand the manufacturer's instructions before making any adjustments or calibrations.		✓	
4	Schedule work with operating personnel, as needed.		✓	
5	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
6	Ensure appropriate site personnel are notified that alarms that may result from testing and to disregard them until testing is completed.	✓	✓	
7	Replace defective control safeties (as work order) found while performing preventive maintenance.	✓		
JOB PERFORMED DURING INSPECTION/SERVICE				
1	Clean and calibrate all controlling instruments (temperature and pressure transducers, etc.) in accordance with manufacturer's instructions and maintenance standard.	✓		
2	Check and clean all electrical contacts and pneumatic orifices.	✓		
3	Check pneumatic tubing for leaks or damage. Repair or replace as required.	✓	✓	
4	Check for bad indicator lights and gauges and replace as necessary.	✓		
5	Test all controllers and set at proper set points.	✓		
6	Check operating data and analyze for proper operation. Note unusual conditions such as compressor surge on maintenance log.	✓	✓	

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- General Services Administration (GSA) Public Building Service. 2012. *Public Buildings Maintenance Standards Final*. October 1.

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at [\(Provide Link to OEM Manual/Asset Library\)](#)

Additional Notes:

HVAC

Control

Panel.

BL

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR COMPRESSOR

SITE AND BLDG #:

PA013-01

LOCATION/RM #:

Becker

WO# 10921

ASSET # 5338

MECHANIC
SIGNATURE:

DATE:

START TIME:

8:30

FINISH TIME:

8:48

2/3/19

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Perform normal tour checks and operations. Perform a visual inspection of the air system, noting any obvious leaks or portions of the air distribution network that may be subject to physical damage.	✓		
2	Change compressor crankcase oil (annually).		NA	
3	Clean or replace air intake filter, as needed.		NA	
4	Check air dryer, automatic condensate drains, and air tank for proper operation. Manually blow down condensate tank if needed. Clean condenser coils and cover grills, if applicable.		NP	
5	Inspect oil separators for any sign of oil entering the system.		NA	
6	Inspect belt alignment and condition. Adjust or replace belts as required. Belts should be replaced in complete sets.		NP	
7	Check for corrosion and scale on water cooled units.	✓		
8	Clean heat exchange surfaces.		NP	
9	Check accuracy of gauges with calibrated test gauge.	✓		
10	On two stage compressor, check intermediate pressure.		NP	
11	Test relief valves, replace if leaking or the relief range is incorrect. Do not readjust safety relief valves in the field.		NP	
12	Check cut in and cut out of compressor pressure controller, readjust if necessary for proper air pressure requirements. Do not exceed ASME maximum tank pressure.		NA	
13	Check to make sure belt guard is installed prior to putting air compressor back in service.		NA	
14	Check if air compressor is running excessively or frequently cycling on and off (possible leaks).		NP	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

2 PC

ATC

PL