

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

P2 013-02

MECHANIC
SIGNATURE:

[Signature]

DATE:

9/3/19

LOCATION/RM #

m61

WO#

10837

ASSET #

6034

START TIME:

0640

FINISH TIME:

0642

CHECKED/COMPLETED		DATE/TIME		INITIALS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule and coordinate work with operating personnel.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
4	Open and tag switch.				
5	Inspect visual condition of wiring. Look for evidence of overheating.				
6	Check for proper light operation.				
7	Test operation of automatic switches/ time clock/ photocells if applicable.				
8	Inspect light pole and mounting devices for deficiencies.				
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

10

P-

[Handwritten mark]