

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Pa 017

Date of Visit: 3/21/19

Contractor Personnel on Site:

1. TONY Geras
2. Jim Geertgen
3. Scott Werry
4. _____
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 7720
2. 7988
3. 7822
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jay Geertgen Date: 3-21-19

Signed: Jay Geertgen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Leslie Ladd Date: 3/21/19

Signed: Leslie Ladd

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PA 017-01 Date of Visit: 3/21/19

Contractor Personnel on Site:

1. Tony Grano
2. Jim Geertsen
3. Scott Berry
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 7617
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertsen Date: 3-21-19
Signed: Jim Geertsen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Leslie Loh Date: 3/21/19
Signed: Leslie Loh

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CIRCULATING AND BOOSTER PUMPS

SITE AND BLDG #: *P2017-01*LOCATION/RM #: *Barker WO# 7720* ASSET # *4996*MECHANIC
SIGNATURE: *John O'Brien*DATE: *3/21/19*START TIME: *800*FINISH TIME: *810*

CHECK ITEM#	CHECKPOINT DESCRIPTION	PASSED/COMPLETED	NOTES/ACCTIONS	NOTES/COMPLETED/CHANGED/NO PROBLEMS/EXPLANATION	
				YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication atleast annually.				
2	Inspect couplings and check for any pump seal leaks.				
3	Check motor mounts and vibration pads				
4	Tighten all pump flanges.				
5	Visually check pump alignment and coupling				
6	Inspect electrical connections				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes:

*2 pc**Pump # 1**VALVED OFF + SHUT OFF*