

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 017

Date of Visit: 6/13/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geertgens
3. Scott Werry

4. _____
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 9100 9339
2. 9288 9470
3. 9416
4. 9138

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens

Date: 6-13-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Londm leski

Date: 6/13/19

Signed: [Signature]

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

Facility/Building: PA 017

Date of Visit: 6/13/19

Contractor Personnel on Site:

1. Tony Green
2. Jim Beertgens
3. Scott Werry

4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 9236
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Beertgens

Date: 6-13-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: London, Leshi

Date: 6/13/19

Signed: [Signature]

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST VEHICLE EXHAUST REMOVAL

SITE AND BLDG #:

PA 017 -02

LOCATION/RM #: GMS

WO# 9339

ASSET # 8059

MECHANIC
SIGNATURE: 

DATE:

6/13/19

START TIME:

930

FINISH TIME:

940

ITEM NO.	DESCRIPTION	TASKS COMPLETED		NOTES/ACTIONS (if tasks completed, check box and provide explanation)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
3	Start and stop fan with local switch			
4	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.			
5	Inspect, adjust belts and pulleys. Replace belt as needed.			
6	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.			
7	Inspect fan for bent blades, unbalance, excessive noise and vibration.			
8	Clean fan as needed.			
9	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.			
10	Repair as needed			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: