

ATTACHMENT J-0200000-05  
FORMS

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 042

Date of Visit: 5.3.19

Contractor Personnel on Site:

1. Gary Bartzel
2. \_\_\_\_\_
3. \_\_\_\_\_

4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Work Performed:

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8236
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Gary Bartzel

Date: 5.3.19

Signed: Gary Bartzel

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: JAMES T JOSEPH SOT Date: 5.3.19

Signed: J. T. Jr

E-Mail: james.t.joseph3.mil@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
THERMOSTATSSITE AND BLDG #: PA 042MECHANIC  
SIGNATURE: May BecteDATE: 5.3.19LOCATION/RM #: 117/118 WO# 8236 ASSET # 54910START TIME: 8:00FINISH TIME: 8:30

ITEM/S LINE	CHECKPOINT DESCRIPTION	TASK COMPLETION		NOTES//COMMENTS (IF TASK COMPLETED, PLEASE PROVIDE INFORMATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
<b>TO BE PERFORMED DATE EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	/		
2	Review all zone set points at the server.	/		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set      Act  
70      66

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

SITE AND BLDG #: DA 042LOCATION/RM #: Cage WO# 8236 ASSET # 5745MECHANIC  
SIGNATURE:Nancy BetselDATE: 5-3-19

START TIME:

8:00

FINISH TIME:

8:30

CHECK ITEM	CHECKPOINT DESCRIPTION	BASIC COMPLETION		NOTES/AGGREGATE (DESCRIBE DEFICIENCIES FOUND)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		✓	
2	Review all zone set points at the server.	✓		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.		✓	
6	If applicable, replace battery as needed.		✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set      Act  
60      78

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

SITE AND BLDG #: PAC042LOCATION/RM #: 125 WO# 823C ASSET # 5754MECHANIC  
SIGNATURE: Henry ReiterDATE: 5.3.19START TIME: 8:00FINISH TIME: 8:30

CHECK ITEM	CHECK ITEM DESCRIPTION	PASSED/COMPLETED		NOTES/ACCTIONS (DESCRIBE DEFECTS/CHANGES MADE/PROVIDED INFORMATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	✓		
2	Review all zone set points at the server.	✓		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	✓		
6	If applicable, replace battery as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Act Set  
58  
60

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

SITE AND BLDG #: PA 042  
 LOCATION/RM #: 115 WO# 6236 ASSET # 6335

MECHANIC  
 SIGNATURE: Hayley Bentz DATE: 5.3.19  
 START TIME: 8:00 FINISH TIME: 8:30

ITEMS NUMBER	ITEMS/DESCRIPTION	PARK COMBINING WIRELESS		NOTES//ACTION
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	/		
2	Review all zone set points at the server.	/		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set	Act
55	75
55	73
55	74
55	73