

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA042

Date of Visit: 6/11/19

Contractor Personnel on Site:

1. Tony Green
2. Tom Gault
3. Scott Berry

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1.	<u>9109</u>	<u>9340</u>
2.	<u>9289</u>	<u>9455</u>
3.	<u>9418</u>	
4.	<u>9145</u>	

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Tim Greftgen

Date: 6-11-19

Signed: Tim Greftgen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT JOSEPH, JAMES

Date: 11 JUNE 19

Signed: James F. Joseph

E-Mail: James.F.joseph3.mil@mail.mil

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: Pro 42-01 Date of Visit: 6/11/19

Contractor Personnel on Site:

1. Tony Grimes
2. Sam Geertgens
3. Scott Wiley
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 9225
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Tim Geertgens Date: 6-11-19
Signed: Tim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sgt. JOSEPH, JAMES T Date: 11 JUNE 19
Signed: James T. Joseph

E-Mail: James.t.joseph.3.mil@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: Pn 042-02

LOCATION/RM #: CM1 WO# 9455 ASSET # 0270

MECHANIC
SIGNATURE:

DATE:

01/18

START TIME:

020

FINISH TIME:

1240

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
3	For gsa/oil heaters:			
4	1. Remove access panels if applicable.	/		
5	2. Check the fire box liner or refractory for cracks and leaks.	/		
6	3. Check all gas lines for leaks. Repair as needed.	/		
7	2. Clean dirt from heater, vaccuming is preferred.	/		
8	3. Check operation of gas valve.	/		
9	4. Check for gas leaks.	/		
10	5. Check operation of thermostat.	/		
11	6. If applicable, replace primary air intake filter.	/		
	7. As needed, clean spark electrode and reset gap, replace if necessary.	/		us jk
8	8. Inspect flue pipe and connections.	/		
9	9. If applicable, inspect and clean outside air blower and blower intake.	/		
10	10. Inspect unit for proper operation.	/		
11	11. Inspect unit for overall condition and recommend for replacement or other needed repairs.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For


B/K

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: P2042-02

LOCATION/RM #: ~~Wetzel~~ ~~Pod~~ WO# 9455

ASSET # 4514

MECHANIC
SIGNATURE:

100

DATE: 6/11/18

START TIME:

FINISH TIME: 115

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
3	For gsa/oil heaters:			
4	1. Remove access panels if applicable.	/		
5	2. Check the fire box liner or refractory for cracks and leaks.	/		
6	3. Check all gas lines for leaks. Repair as needed.	/		
7	2. Clean dirt from heater, vaccuming is preferred.	/		
8	3. Check operation of gas valve.	/		
9	4. Check for gas leaks.	/		
10	5. Check operation of thermostat.	/		
11	6. If applicable, replace primary air intake filter.	/		
	7. As needed, clean spark electrode and reset gap, replace if necessary.	/		
	8. Inspect flue pipe and connections.	/		
	9. If applicable, inspect and clean outside air blower and blower intake.	/		
	10. Inspect unit for proper operation.	/		
	11. Inspect unit for overall condition and recommend for replacement or other needed repairs.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For

BK