

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PRO79

Date of Visit: 4/10/19

Contractor Personnel on Site:

1. Tony Lazar
2. Tom Geerfroy
3. GARY Beitzel

- 4.
- 5.
- 6.

Work Performed:

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8241
2. 8328
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geerfroy

Date: 4-10-19

Signed: Jim Geerfroy

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Josh Sutton GS-11

Date: 10 Apr 19

Signed: JL Sutton

E-Mail: joshua.e.sutton2.civ@mail.mil

OTHER RECURRING SERVICES CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PA 029 Date of Visit: 4/10/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geragos
3. Greg Befred

- 4.
- 5.
- 6.

Work Performed:

Other Recurring Services

1. 833r
- 2.
- 3.
- 4.

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Jim Geragos Date: 4-10-19  
Signed: Jim Geragos

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Josh Sutton Date: 10 Apr 19  
Signed: JL Sutton

E-Mail: joshua.e.sutton.2.civ@mail.mil

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**LIGHTING, OUTSIDE**

SITE AND BLDG #: A07

LOCATION/RM #: M-1 WO# 8335 ASSET # 7471

MECHANIC  
SIGNATURE:

DATE: \_\_\_\_\_

4/10/15

START TIME:

**FINISH TIME:**

CHECK POINT	CHICKEN INSTRUCTIONS	TASK COMPLETION		NOTES/ACTIONS (IF TASK NOT COMPLETED, CHECKING TO PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule and coordinate work with operating personnel.		/	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.		/	
2	Inspect visual condition of wiring. Look for evidence of overheating.		/	
3	Check for proper light operation.		/	
4	Test operation of automatic switches/ time clock/ photocells if applicable.		/	
5	Inspect light pole and mounting devices for deficiencies.		/	
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.		/	
Note: The technician shall perform any repairs identified during PM up to \$250.00.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

to be performed by  
Additional Notes:

2

15

Rough

1 Light over on Left Head Score of BMN  
1 Light over on Right Head Score of BMN