

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: P0082

Date of Visit: 8/8/19

Contractor Personnel on Site:

1. TONY LARUS
2. JIM GERTGENS
3. JEFF WELCH

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 10228
2. 10402
3. 10244
4. 10471

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Gertgens

Date: 8-8-19

Signed: Jim Gertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: JAMES T. WOOLF GS-9/MA Date: 8 Aug 19

Signed: James T. WOOLF

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: Pr 087-01 Date of Visit: 8/8/18

Contractor Personnel on Site:

1. Tom Lazzaro
2. Tom Gaskins
3. _____
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 10369
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Tom Lazzaro Date: 8/8/18
Signed: Tom Lazzaro

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: JAMES T. WOLFF GS-1/AN Date: 8 AUG 18

Signed: James T. Wolff

E-Mail: James.t.wolff.civ@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOMESTIC HOT WATER HEATER - GAS

SITE AND BLDG #: PA 087 - 02

LOCATION/RM #: CM

WO# 1421

ASSET # 7005

MECHANIC
SIGNATURE: *John*

DATE: 8/8/18

START TIME: 840

FINISH TIME: 852

NOTES/ ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal	/	
3	Use caution when working with natural gas fired equipment. Be aware of any smells (rotten egg) that could be a natural gas leak.	/	
4	Do not allow any open flames around equipment.	/	
1	Attach drain hose. Drain several gallons from tank to remove	/	
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	/	
3	Check all connections - electric, gas and water. Tighten as necessary.	/	
4	Check operation and setting of aquastat. Check hot water temperature with dial thermometer, and set aquastat at	/	NA
5	Drain storage and expansion tanks, and flush to remove sediment, scale, and solid at bottom of tank.	/	NA
6	Clean sight glasses on tanks.	/	NA
7	Clean strainer, check condition of traps. Report and repair leaks.	/	NA
8	Clean pump, controls, switches, and starters. Check operation of pump and condition of pump seal or packing, and replace as required.	/	NA

K00-048CMI Management Inc.

9 If applicable, Remove and inspect Anode, replace if necessary
10 Clean up work area and remove trash.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker
Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHILLER CONTROL PANEL (ANNUAL)

ACTIVITY AND BLDG #:

PA 687-02

LOCATION: OM 5041 Asset# 7225

MECHANIC
SIGNATURE:

DATE: 8/8/11

START TIME:

938

FINISH TIME: 940

ITEM #	DESCRIPTION	CHECKING INSTRUMENTS	COMPLETION	SPECIAL INSTRUCTIONS		NOTES/AVAILABILITY
				WORK COMPLETED	NOTES	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.					
2	Read and understand the manufacturer's instructions before making any adjustments or calibrations.					
4	Schedule work with operating personnel, as needed.					
5	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.					
6	Ensure appropriate site personnel are notified that alarms that may result from testing and to disregard them until testing is completed.					
7	Replace defective control safeties (as work order) found while performing preventive maintenance.				NP	
						TO BE PERFORMED DATE: 10/11/2011 INSPECTION SERVICE
1	Clean and calibrate all controlling instruments (temperature and pressure transducers, etc.) in accordance with manufacturer's instructions and maintenance standard.				NP	
2	Check and clean all electrical contacts and pneumatic orifices.				NP	
3	Check pneumatic tubing for leaks or damage. Repair or replace as required.				NP	
4	Check for bad indicator lights and gauges and replace as necessary.				NP	
5	Test all controllers and set at proper set points.				NP	
6	Check operating data and analyze for proper operation. Note unusual conditions such as compressor surge on maintenance log.				NP	

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- General Services Administration (GSA) Public Building Service, 2012. *Public Buildings Maintenance Standards Final*. October 1.

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link to OEM Manual/Asset Library](#))

Additional Notes:

Sure Long Control Panel