

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PP 096

Date of Visit:

6/21/19

Contractor Personnel on Site:

1. Tony Geertgens
2. Jim Geertgens
3. Scott Werry

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1.	<u>9106</u>	<u>9143</u>
2.	<u>9270</u>	<u>9327</u>
3.	<u>933</u>	<u>9471</u>
4.	<u>9372</u>	

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens

Date: 6-21-19

Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mitchell Morrison SS6 Date: 21 June 2019

Signed: Mitchell Morrison

E-Mail: mitchel.w.morrison.mil@mail.mil

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: P096-01

Date of Visit: 6/21/19

Contractor Personnel on Site:

1. Tony (2nd)
2. Tom Geestgens
3. Scott (empty)

- 4.
- 5.
- 6.

Work Performed:

Other Recurring Services

9222

- 2.
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Tom Geestgens

Date: 6-21-19

Signed: Tom Geestgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mitchell Morrison SSG Date: 21 June 2019

Signed: Mitchell Morrison

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #:

Pn 056-02

LOCATION/RM #:

CM# 9327 WO# 8041 ASSET # 8041

MECHANIC
SIGNATURE:

START TIME:

DATE:

6/21/18

FINISH TIME:

1045

ITEM # PROCEDURE	DESCRIPTION	SPECIAL INSTRUCTIONS	TASK COMPLETED		NOTES/ACTIONS (IF TASK NOT COMPLETED OR CHANGED, PROVIDE DETAILS)
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			-	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			-	
1	Start and stop fan with local switch			-	
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.			-	
3	Inspect, adjust belts and pulleys. Replace belt as needed.			-	
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.			-	
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.			-	
6	Clean fan as needed.			-	
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.			-	
8	Repair as needed			-	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes: