

SAUNTERS

Date _____ Pages of _____

SENTRY MECHANICAL
1724 Leachburg Road
Pittsburgh, PA 15206
(412) 798-3206
Fax (412) 798-3206
Phone # NA

Customer Name: Congress Army Reserve
Address: 44 Schenck Lane
Location: Congress Army Reserve
Equipment Type: Exhausting Pump
Model #: 33, HUC, PHASE 2
Voltage: 208/120
Filtration: 4' x 18" x 14"
Filter(s) qty., size & type: N/A
Baffle(s) qty., size & type: N/A
Accessibility: Front
Evaluation: Pump unit is leaking & will need replaced
pump is covered at old work is isolated

Make: Bell & Gossett
Serial #: 12 L566
Equipment Location: Boiler Room
Area Served: Exhausting Vap.

Mechanical System Evaluation
One copy per piece of equipment

Status: Incomplete ☐ Complete ☒
Priority 1-5: ☐ (5 Being High)

Drawn: Dan
Service Tech:
YELLOW - Job File
Date: _____
Reviewed By: _____
TE - Service Department
NED GRAPHIC SERVICE (412) 369-6166 244520

3-18 PINK -



