

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Palisades

**LOCATION/RM #:** 201E   **WO#** 8278   **ASSET #** 55a6

**MECHANIC SIGNATURE:** 

**DATE:**

4-15-19

**START TIME:** 10:25   **FINISH TIME:** 10:30

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</b>
		<b>YES</b>	<b>NO</b>	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check time-of-day schedule to confirm consistency with facility operation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Adjust schedule as needed. If applicable, replace battery as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**



**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pa 166

**DATE:** 4-15-19

**LOCATION/RM #:** 201    **WO#** 828    **ASSET #** 55G7

**START TIME:** 10:25    **FINISH TIME:** 10:30

**MECHANIC SIGNATURE:** 

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.			
2	Review all zone set points at the server.			
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.			
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.			
5	Check time-of-day schedule to confirm consistency with facility operation.			
6	If applicable, replace battery as needed.			

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**



**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pal 66

**LOCATION/RM #:** 8205 **WO#** S228 **ASSET #** 5598

**MECHANIC SIGNATURE:**   
**DATE:** 4-15-19

**START TIME:** 10:40 **FINISH TIME:** 10:45

CHECK POINT	CHECK POINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pa 166

**MECHANIC SIGNATURE:** J. S. **DATE:** 4-15-19

**LOCATION/RM #:** 205 **WO#** 8278 **ASSET #** 55G9

**START TIME:** 10:40 **FINISH TIME:** 10:50

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (If Task Complete is checked no, provide explanation)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓	✗	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✗	✓	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	✓	✓	
2	Review all zone set points at the server.	✓	✓	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓	✓	
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓	✓	
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	✓	✓	
6	If applicable, replace battery as needed.	✓	✓	

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

**THERMOSTATS**

**SITE AND BLDG #:** DaV66

**MECHANIC SIGNATURE:** [Signature]

**DATE:** 4-15-19

**LOCATION/RM #:** 205    **WO#** 8278    **ASSET #** 5600

**START TIME:** 10:45

**FINISH TIME:** 10:50

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturer's diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**



**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pa 166

**MECHANIC SIGNATURE:** 

**DATE:** 4-15-19

**LOCATION/RM #:** 204    **WO#** 8278    **ASSET #** 5615

**START TIME:** 10

**FINISH TIME:** 10:05

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pa 166  
**LOCATION/RM #:** 202 **WO#** 8278 **ASSET #** 5624

**MECHANIC SIGNATURE:**   
**DATE:** 4-15-19

**START TIME:** 10:10 **FINISH TIME:** 10:15

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDED EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

*AC*

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pallets

**LOCATION/RM #:** Attic **WO#** 8276 **ASSET #** 5629

**MECHANIC SIGNATURE:** JK

**DATE:** 4-15-19

**START TIME:** 10:16

**FINISH TIME:** 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**



**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Da 166

**LOCATION/RM #:** Hall    **WO#** 8275    **ASSET #** 5630

**MECHANIC SIGNATURE:** J. S.

**DATE:** 4-15-19

**START TIME:** 10:15    **FINISH TIME:** 10:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	✓		
2	Review all zone set points at the server.	✓		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation.	✓		
6	If applicable, replace battery as needed.	✓		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

*BK*

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

SITE AND BLDG #: Do 116

WO# 8278 ASSET# 5631

MECHANIC SIGNATURE: DK

DATE: 4-15-19

START TIME: 10:25

FINISH TIME: 10:30

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (If TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	<input checked="" type="checkbox"/>		
6	If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

*BY*

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**THERMOSTATS**

**SITE AND BLDG #:** Pal 66

**MECHANIC SIGNATURE:** 

**DATE:** 4-15-19

**LOCATION/RM #:** 5 stairs    **WO#:** 8278    **ASSET #:** 5716

**START TIME:** 10:20

**FINISH TIME:** 10:25

CHECK POINT	CHECK POINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.	<input checked="" type="checkbox"/>		
2	Review all zone set points at the server.	<input checked="" type="checkbox"/>		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	<input checked="" type="checkbox"/>		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	<input checked="" type="checkbox"/>		
5	Check time-of-day schedule to confirm consistency with facility operation.	<input checked="" type="checkbox"/>		
6	Adjust schedule as needed.  If applicable, replace battery as needed.	<input checked="" type="checkbox"/>		

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**

  
Page 1 of 1