

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **DEHUMIDIFIER**

SITE AND BLDG #: Pa 16601 **MECHANIC SIGNATURE:**  **DATE:** 5-28-19

LOCATION/RM #: 608 vault **WO#** 8744 **ASSET #** 5035 **START TIME:** 3:10 **FINISH TIME:** 3:10

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check water inlet and outlet for any leaks, repair as needed.	✓		
2	Clean and/or replace filter as needed.	✓		
3	If applicable, check hours per usage, replace tanks's as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: