

SITE AND BLDG #:	292	BUILDING	PA051-01
LOCATION/RM #:		WO#	7492
		ASSET #	2759
			7287

MECHANIC
SIGNATURE: *[Signature]*
DATE: 03-13-2019

START TIME: 9:00

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X			
2	During the first inspection, check that: a) All air terminals (lightning rods) are interconnected. b) At least two down conductors are installed with their own ground connection.	X			
1	Inspect air terminals for corrosion and rigid attachment to structure.	X			
2	Examine conductors and all connections for corrosion, strong mechanical joints which provide good electrical conductivity, and loose or broken fasteners.	X			
3	Check for loops, sharp bends (less than 8" radius) and frayed horizontal and vertical conductors.	X			
4	Check for damaged guards and down conductors.			X	
5	Inspect grounding attachment for permanency and corrosion (if practical).			X	
6	Test resistance to ground for each down conductor.			X	
7	Clean up work area and remove debris.	X			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

13

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: 292

Date of Visit: 03/13/2019

Contractor Personnel on Site:

- | | |
|----------------|----------|
| 1. Gene Lutz | 4. _____ |
| 2. Jeff Galamb | 5. _____ |
| 3. _____ | 6. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____

Inspection, Testing, and Certification

1. Inspect Lightning Protection System
2. _____
3. _____
4. _____

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

Service Calls – Service Call Number and Description

1. _____
2. _____
3. _____


Over and Above Repair Work – Order Number and Description of Work Completed

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Jeffrey L Galamb

Date 03/11/2019


Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: 

Date: 3/13/19

Signed: 

E-Mail: _____