

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: W6 038

Date of Visit: 7/2/19

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Tony Czarus</u> | 4. _____ |
| 2. <u>Jim Geertgens</u> | 5. _____ |
| 3. <u>Scott Werry</u> | 6. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

- | | |
|----------------|-------|
| 1. <u>9867</u> | _____ |
| 2. <u>9756</u> | _____ |
| 3. <u>9931</u> | _____ |
| 4. _____ | _____ |

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens

Date: 7-2-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Share Fabian

Date: 7-2-19

Signed: [Signature]

E-Mail: _____

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV038

Date of Visit: 7/2/19

Contractor Personnel on Site:

1. Tony Lozano
2. Jim Geertjens
3. Scott Werry

4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 9823
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertjens

Date: 7-2-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shane Fabian

Date: 7-2-19

Signed: [Signature]

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST AIR COMPRESSOR

SITE AND BLDG #: WU 038-02

LOCATION/RM #: OMS WO# 9756 ASSET # 6742

MECHANIC
SIGNATURE: 

DATE: 7/2/18

START TIME: 9/5

FINISH TIME: 930

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		—	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		—	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Perform normal tour checks and operations. Perform a visual inspection of the air system, noting any obvious leaks or portions of the air distribution network that may be subject to physical damage.	—		
2	Change compressor crankcase oil (annually).		u/p	
3	Clean or replace air intake filter, as needed.		u/p	
4	Check air dryer, automatic condensate drains, and air tank for proper operation. Manually blow down condensate tank if needed. Clean condenser coils and cover grills, if applicable.		u/p	
5	Inspect oil separators for any sign of oil entering the system.	—		
6	Inspect belt alignment and condition. Adjust or replace belts as required. Belts should be replaced in complete sets.	—		
7	Check for corrosion and scale on water cooled units.	—		
8	Clean heat exchange surfaces.	—		
9	Check accuracy of gauges with calibrated test gauge.	—		
10	On two stage compressor, check intermediate pressure.	—		
11	Test relief valves, replace if leaking or the relief range is incorrect. Do not readjust safety relief valves in the field.	—		
12	Check cut in and cut out of compressor pressure controller, readjust if necessary for proper air pressure requirements. Do not exceed ASME maximum tank pressure.	—		
13	Check to make sure belt guard is installed prior to putting air compressor back in service.	—		
14	Check if air compressor is running excessively or frequently cycling on and off (possible leaks).	—		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

B/C