

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WVQ38

Date of Visit: 5/2/19

Contractor Personnel on Site:

1. Tony Brown
2. Jim Gertzen
3. Gary Beitzel

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8498
2. 8613
3. 8801
4. 8702

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Gertzen

Date: 5-2-19

Signed: Jim Gertzen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Denis, Shaw SSG Date: 20190502

Signed: Denis Shaw

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: WV 038 Date of Visit: 5/2/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geertzen
3. Gary Bartzel

- 4.
- 5.
- 6.

Work Performed:

Other Recurring Services

1. 8573
- 2.
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: John Geertzen Date: 5-2-19
Signed: John Geertzen

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Dennis, SSG, SSG Date: 20190505
Signed: Dennis

E-Mail: Ssgw.s.m.d

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOMESTIC HOT WATER HEATER - ELECTRIC

SITE AND BLDG #: WU 038-02LOCATION/RM #: 6M WO# 9202ASSET # 7024MECHANIC
SIGNATURE:
START TIME: 1000DATE: 5/2/18FINISH TIME: 1010

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
3	Attach drain hose. Drain several gallons from tank to remove	/		
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	/		
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters	/		
4	Check operation/ setting of aquastat. Check hot water temperature with dial thermometer, set aquastat at minimum		NA	
5	Check amperage draw of upper and lower elements and compare to name plate data.	/		
6	Clean element contacts, and check for proper closing under load.		20	
7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing, and replace as required.		NA	
8	If applicable. Remove and inspect Anode, replace if necessary		NA	
9	Clean up work area and remove trash.	/	NA	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.