

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV053

Date of Visit: 3/25/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geertgens
3. Scott Werry

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. <u>7730</u>	<u>7783</u>
2. <u>7768</u>	<u>7949</u>
3. <u>8023</u>	<u>7732</u>
4. <u>7734</u>	

CERTIFICATION OF WORK

BK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 3-25-19

Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Don Showalter Date: 25 MAR 19

Signed: DS

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: WU 053-01 Date of Visit: 3/25/19

Contractor Personnel on Site:

1. <u>Tony Lorus</u>	4. _____
2. <u>Jon Geertges</u>	5. _____
3. <u>Scott Berry</u>	6. _____

Work Performed:

Other Recurring Services


1. <u>7548</u>	4. _____
2. _____	5. _____
3. _____	6. _____
4. _____	7. _____

CERTIFICATION OF WORK

DC

To be signed by the Contractor:

Print Name: Jon Geertges Date: 3-25-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Don Showalter Date: 25 MAR 19

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TANKS, WATER STORAGE

SITE AND BLDG #: WV083-a7LOCATION/RM #: Boiler Room WO# 773 ASSET # 5016MECHANIC
SIGNATURE: DATE: 3/2/19START TIME: 8:00FINISH TIME: 8:08

CHECK ITEM	CHECK ITEM DESCRIPTION	TASK COMPLETED		NOTES/ACCTIONS (ENTER COMMENTS/REMARKS TO PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Clean up work site.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes:

