

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV053

Date of Visit: 6-24-19

Contractor Personnel on Site:

1. Jim Geertgens

2. Scott Vicky

3. _____

4. _____

5. _____

6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 9084

9368

9319

2. 9201

~~9071~~

9393

3. 9293

9083

9294

4. 9310

9295

9422

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens

Date: 6-24-19

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Adrian P Popik

Date: 2019 0624

Signed: _____

E-Mail: _____

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV 053 Date of Visit: 6-24-19

Contractor Personnel on Site:

1. Jim Geggans
2. Scott Werry
3. _____
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 9201
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geggans Date: 6-24-19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Andrew P. Poirie Date: 2019.06.24

Signed: [Signature]

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST GREASE TRAP

SITE AND BLDG #: WU053-1LOCATION/RM #: WO# 9310 ASSET # 7493MECHANIC
SIGNATURE: DATE: 6-24-19START TIME: 1045FINISH TIME: 1100

CHECK ITEM	DESCRIPTION	STATUS		SPECIAL INSTRUCTIONS	NOTES/ACTIONS (IF STATUS COMPLETION OR REPAIRS REQUIRED, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
3	Insure proper grease disposal.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.				
2	Remove lid. If the trap is equipped with removable baffles, remove them.				
3	Make sure the flow restrictor on the inflow pipe is present.				
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.				
5	Replace lid and baffles.				
6	Return (or fill) water to grease trap.				
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: