



## OneCIS Insurance Company

95 Oakwood Rd  
Lake Zurich, IL 60047  
(855) 593-5115  
[www.us.bureauveritas.com](http://www.us.bureauveritas.com)



May 20, 2019

44110-007209.00

USARC BG J Sumner Jones  
11 Veteran Blvd  
Romney, WV 26757  
[bernie.koblinsky@cmimgmt.com](mailto:bernie.koblinsky@cmimgmt.com)

**RE: Jurisdictional Inspection:**  
USARC BG J Sumner Jones  
11 Veteran Blvd  
Romney, WV 26757

Thank you for the consideration I received during my visit on May 2, 2019 at your facility listed above. The purpose of the visit was to perform the non-jurisdictional inspections of the objects listed below to determine compliance with jurisdictional laws and regulations. I was accompanied by SFC Michael Moore during my visit.

The inspections were performed on behalf of CMI Management, Inc (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2000	Cast Iron	WV038-01	CI	See Below
2000	Cast Iron	WV038-02	CI	See Below
2000	Cast Iron	WV038-03	CI	None

The following observations were noted during the inspection of this equipment:

- ***Fittings, attachments, and accessible parts were closely examined and found in satisfactory condition. No adverse conditions were noted with respect to controls and safety valves.***

As a result of this inspection, there were 2 recommendations suggested.

In order for the certificate(s) of operation to be renewed, all code violations must be cleared.

The recommendation(s) made to correct the deficiency(s) are listed below. Please indicate any action(s) taken on these recommendation(s), by calling me at the number listed below.

The next inspection is tentatively scheduled to be completed by 08/02/2019.

## **Recommendations**

The following recommendation(s) must be completed before an operating permit can be issued.

No. **2019-05-1** - Complete within 90 days  
WMSD-WV038-01 located in Boiler Room

**Condition:** The ASME code stamping plate is missing or indistinct

**Requirement:** Contact the manufacturer to have a replacement ASME code stamping decal applied.

No. **2019-05-2** - Complete within 90 days  
WMSD-WV038-02 located in Boiler Room

**Condition:** The ASME code stamping plate is missing or indistinct.

**Requirement:** Contact the manufacturer to have a replacement ASME code stamping decal applied.

Please contact me by phone at 571-373-0998 or by e-mail at [william.johnson@onecis.com](mailto:william.johnson@onecis.com) if there are any questions and to clear any recommendations.

Sincerely,

*William Garth Johnson*

William Garth Johnson  
B&M Jurisdictional Specialist

## **DISTRIBUTION**

Cc:

Thomas Kovach, OneCIS Insurance  
[Thomas.kkovach@onecis.com](mailto:Thomas.kkovach@onecis.com)

## **FILE**

This document is advisory in nature. Reports or certificates provided in connection with any state-required boiler or pressure vessel inspection do not mean that all hazards or conditions were controlled at the time of the inspection. No liability is assumed by the information contained in this document.

# Location Detail

Search Criteria: Country: USA; NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Status: Active; Order Results by: Location Name; Then Order by: Address

Policy Name: CMI Management, Inc (US Army Reserve Offices) Policy Number: 44110-007209.00

Location: USARC BG J Sumner Jones Location ID: 3933729

Address: 11 Veteran Blvd - Romney, WV 26757 Phone:

County: Hampshire FIPS: 54027 NOB/SIC:

Primary Contact: Bernie Koblinsky - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com

Billing Contact: Bernie Koblinsky - 5285 Shawnee Rd Ste 510 Alexandria, VA 22312-2334 - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com

Registered Owner's Email (NYC Locations Only):

Juris #	Alt Juris #	Type	Use	NB	Serial	Manufacturer	Year Built	Due Date	Inspect Type	Status	Location
WV038-01		Cast Iron	Hot Water Supply	CI		WMSD	2000	05/02/2020	Recurring Cert	Active	Boiler Room
WV038-02		Cast Iron	Hot Water Supply	CI		WMSD	2000	05/02/2020	Recurring Cert	Active	Boiler Room
WV038-03		Cast Iron	Hot Water Supply	CI	S?N64252253	Burnham	2000	05/02/2020	Recurring Cert	Active	Boiler Room

Total Objects at this Location: 3

Total Objects 3

Total Locations 1

Total Active Objects 3

ATTACHMENT J-0200000-05  
FORMS

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WU043 Date of Visit: 5/2/19

Contractor Personnel on Site:

1. Scott Heffy
2. Craig Bell
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Boiler inspection
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Craig Bell Date: \_\_\_\_\_

Signed: Craig Bell

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Supply NCO  
Print Name/Rank: SSG Sacco, Steven S. Date: 20190502

Signed: Steve S. Sacco

E-Mail: Steve.S.Sacco.mil@mail.mil