

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PA 051-19401 Date of Visit: 5-1-19

Contractor Personnel on Site:

1. Gary Bartz
2. Craig Bell
3. _____
4. _____
5. _____
6. _____

Work Performed: Boiler inspection

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Craig Bell Date: 5-1-19
Signed: Craig Bell

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: NATHAN HAUSER / 55GT Date: 20190501
Signed: NATHAN HAUSER

E-Mail: _____



OneCIS Insurance Company

95 Oakwood Rd
Lake Zurich, IL 60047
(855) 593-5115
www.us.bureauveritas.com



May 21, 2019

44110-007209.00

Mr. Bernie Koblinsky CMI
Johnstown Aviation Support Facility
194 (200) Aviation Dr
Johnstown, PA 15902-7250
bernie.koblinsky@cmimgmt.com

RE: Jurisdictional Inspection:
Johnstown Aviation Support Facility
194 (200) Aviation Dr
Johnstown, PA 15902-7250

Thank you for the consideration I received during my visit on May 1, 2019 at your facility listed above. The purpose of the visit was to perform the jurisdictional inspections of the objects listed below to determine compliance with jurisdictional laws and regulations. I was accompanied by Gary Beitzel of CMI 412-510-7753 during my visit.

The inspections were performed on behalf of CMI Management, Inc. (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2008	Water Tube	PA051-19401	89483	None
2008	Water Tube	PA051-19402	92345	None
2008	Water Tube	PA051-19403	93775	None
2008	Water Tube	PA051-19404	908708	See Below

The following observations were noted during the inspection of this equipment:

The following safety equipment was operationally tested satisfactorily as follows: spun spindle on the relief valve, emergency shut off, local shut off, low water fuel cut off. Operational controls are located at the base in Fort Dix.

As a result of this inspection, there was 1 recommendation suggested. The OneCIS Operating Certificate is being withheld for the boiler with a code recommendation as listed below. OneCIS Operating Certificates were issued for the 3 boilers in satisfactory condition.

The next inspection is tentatively scheduled to be completed by 05/01/2020.

This document is advisory in nature. Reports or certificates provided in connection with any state-required boiler or pressure vessel inspection do not mean that all hazards or conditions were controlled at the time of the inspection. No liability is assumed by the information contained in this document.

Recommendations

The following recommendation must be completed.

No. **2019-05-1** - Complete
Giannoni-PA051-19404 located in Boiler room

Condition: F-011 flame rod needs replaced (code).

Requirement: F-011 flame rod needs replaced (code).

Please contact me by phone at 724-759-9488 or by e-mail at craig.bell@onecis.com if there are any questions and to clear the recommendation.

Sincerely,

Craig Bell

Craig Bell
Boiler & Machinery Inspection Specialist

DISTRIBUTION

Cc:

Thomas Kovach, OneCIS Insurance
Thomas.kovach@onecis.com

FILE

Location Detail

Search Criteria: Country: USA; NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Status: Active; Order Results by: Location Name; Then Order by: Address

Policy Name: CMI Management, Inc (US Army Reserve Offices) Policy Number: 44110-007209.00

Location: Johnstown Aviation Support Facility Location ID: 3934184

Address: 194 (200) Aviation Dr - Johnstown, PA 15902-7250 Phone:

County: Cambria FIPS: 42021 NOB/SIC:

Primary Contact: Bernie Koblinsky - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com

Billing Contact: Bernie Koblinsky - 5285 Shawnee Rd Ste 510 Alexandria, VA 22312-2334 - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com

Registered Owner's Email (NYC Locations Only):

Juris #	Alt Juris #	Type	Use	NB	Serial	Manufacturer	Year Built	Due Date	Inspect Type	Status	Location
PA051-19401		Water Tube	Hot Water Heating	89483		Giannoni	2008	05/01/2020	Recurring Cert	Active	Boiler room
PA051-19402		Water Tube	Hot Water Heating	92345		Giannoni	2008	05/01/2020	Recurring Cert	Active	Boiler room
PA051-19403		Water Tube	Hot Water Heating	93775		Giannoni	2008	05/01/2020	Recurring Cert	Active	Boiler room
PA051-19404		Water Tube	Hot Water Heating	908708		Giannoni	2008	05/01/2020	Recurring Cert	Active	Boiler room

Total Objects at this Location: 4

Total Objects	4
Total Locations	1
Total Active Objects	4