

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV007 Date of Visit: 7/25/23

Contractor Personnel on Site:

1. Brandon F.
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Service Call Number

CSS# 92285 WO# \_\_\_\_\_

### Description of Repairs

Replaced the water flow switch, suction line sensor, and temperature sensor.  
Checked all unit operations.

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brandon Fulks Date: 7-25-23

Signed: Brandon Fulks

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: JASON BELCHER RFOS Date: 7/25/23

Signed: Jason Belcher 919-802-7094

E-Mail: jason.m.belcher.civ@army.mil