

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY030 Date of Visit: 5/21/2024

Contractor Personnel on Site:

- | | |
|---------------------------------|----------|
| 1. <u>Postler & Jaeckle</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 96226 WO# 14785

Description of Repairs

Replaced condensate pump, filters, belt and fan sheave. Cleaned up area.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Julie Pape Date: 7/30/2024

Signed: *Julie Pape*

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 07/30/2024

Signed: *John F. Granata*

E-Mail: john.f.granata.ctr@army.mil